

Table 3-29 State Power Regulations included in EPA 2023 Reference Case

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|------------------------|---|-----------------|---|---|---|
| Alabama | Alabama Administrative Code Chapter 335-3-8 | NO _x | For combined cycle EGUs which commenced operation after April 1, 2003; For combined-cycle electric generating units fired by natural gas: 4.0 ppmvd at 15% O ₂ (0.0178 lbs/MMBtu), by fuel oil: 15.0 ppmvd at 15% O ₂ : (0.0667 lbs/MMBtu) | 2003 | |
| Arizona | Title 18, Chapter 2, Article 7 | Hg | 90% removal of Hg content of fuel or 0.0087 lbs/GWh annual reduction for all non-cogen coal units > 25 MW | 2017 | |
| | A.A.C. Section R18-2-734 | Hg | 90% removal of Hg content of fuel or 0.0087 lbs/GWh annual reduction for all non-cogen coal units > 25 MW | 2015 | https://regulations.justia.com/states/arizona/title-18/chapter-2/article-7/r18-2-734/ |
| | A.A.C. Section R18-2-703 | SO ₂ | When solid fuel or low sulfur oil is used 1.0 heat input per 3-hour average for installations which commenced construction/major modification prior to May 30, 1972 0.8 lbs/MMBtu heat input per 3-hour average for installations which commenced construction/major modification after May 30, 1972 When high sulfur oil is used 2.2 lbs/MMBtu heat input per 3-hour average | 1993 (amended 2009) | https://regulations.justia.com/states/arizona/title-18/chapter-2/article-7/r18-2-703/ |
| | | NO _x | For steam power generating installations which commenced construction or major alteration after May 30, 1972, on a maximum 3-hour average calculated as nitrogen dioxide: 0.20 lbs/MMBtu heat input when gaseous fossil fuel is fired 0.30 lbs/MMBtu heat input when liquid fossil fuel is fired 0.70 lbs/MMBtu heat input when solid fossil fuel is fired | | |
| | A.A.C. Section R18-2-903 | SO ₂ | 0.8 lbs/MMBtu heat input for liquid fossil fuel or liquid fossil fuel and wood residue | 1993 (amended 2008) | https://regulations.justia.com/states/arizona/title-18/chapter-2/article-9/r18-2-903/ |
| Arizona – Pinal County | Code 22 5-22-960 | SO ₂ | Fossil Fuel Fired Steam Generators on a maximum of 2-hour average calculated as sulfur dioxide: 0.80 lbs/MMBtu heat input when oil is fired for a new source 1.0 lbs/MMBtu heat input when oil is fired for an existing source | Units commenced construction after March 1975 | https://www.pinal.gov/DocumentCenter/View/9686/PCAQCD--Code-of-Regulations-Updated-January-25-2023-PDF |
| | Code 22 5-22-970 | NO ₂ | For Fossil Fuel Fired Steam Generator, on a maximum of 2-hour averages calculated as nitrogen dioxide: 0.20 lbs/MMBtu heat input when gaseous fossil fuel is fired 0.30 lbs/MMBtu heat input when liquid fossil fuel is fired 0.70 lbs/MMBtu heat input when solid fossil fuel is fired | Units commenced construction after March 1975 | https://www.pinal.gov/DocumentCenter/View/9686/PCAQCD--Code-of-Regulations-Updated-January-25-2023-PDF |
| | Code 23-5-1010 | SO ₂ | Combustion turbines: 1.0 lbs/MMBtu heat input | 1993 | https://www.pinal.gov/DocumentCenter/View/9686/PCAQCD--Code-of-Regulations-Updated-January-25-2023-PDF |
| Arizona – Pima County | PCC 17.16.500 | SO ₂ | 0.8 lbs/MMBtu heat input for liquid fossil fuel or liquid fossil fuel and wood residue (for those who obtained an installation permit prior to May 14, 1979 for two or more fuel burning equipment or steam generating installations) | 1993 | https://codelibrary.amlegal.com/codes/pimacounty/latest/pimacounty_az/0-0-14319 |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|---------------------------|--|-----------------|--|-----------------------|---|
| | PCC 17.16.160 | SO ₂ | When solid fuel or oil is used 1.0 heat input per 3-hour average for installations which commenced construction/major modification prior to May 30, 1972 0.8 lbs/MMBtu heat input per 3-hour average for installations which commenced construction/major modification after May 30, 1972 | 1993 | https://codelibrary.amlegal.com/codes/pimacounty/latest/pimacounty_az/0-0-0-13624 |
| | | NO _x | For steam power generating installations which commenced construction or major alteration after May 30, 1972, on a maximum 3-hour average calculated as nitrogen dioxide: 0.20 lbs/MMBtu heat input when gaseous fossil fuel is fired 0.30 lbs/MMBtu heat input when liquid fossil fuel is fired 0.70 lbs/MMBtu heat input when solid fossil fuel is fired | | |
| Arizona – Maricopa County | Rule 322 Power Plant Operations | | -Applies to combustion turbines, steam generating units, and cogen units - Exemption for low use units - <10% calendar year capacity factor (must have permit limit) | June 23, 2021 | https://www.maricopa.gov/DocumentCenter/View/5256/Rule-322---Power-Plant-Operations-PDF?bidId= |
| | | NO _x | Existing steam generating units (commenced before 6/23/2021): 0.1 lb/MMBtu New steam generating units: 30 ppmvd @ 3% O ₂ , gaseous fuel; 40 ppmvd for liquid fuel CTs, new and existing: 42 ppmvd at 15% O ₂ gaseous fuel; 65 ppmvd for liquid fuel (Allows case-by-case RACT alternative to be approved) | | |
| | | CO | 400 ppmvd @ 15% O ₂ for CTs and 3% O ₂ for steam generating units | | |
| | | SO ₂ | Liquid fuel must be 0.05% S or lower | | |
| California | CA Reclaim Market | NO _x | 5.286 MTons annual cap for list of entities in Appendix A of "Annual RECLAIM Audit Report for 2021 Compliance Year" (304 entities) | 1994 | https://www.aqmd.gov/docs/default-source/reclaim/reclaim-annual-report/2021-reclaim-report.pdf?sfvrsn=6 |
| | | SO ₂ | 2.219 MTons annual cap for list of entities in Appendix A of "Annual RECLAIM Audit Market Report for the 2021 Compliance Year" (304 entities) | | |
| | CA AB 32 | CO ₂ | Power sector and Non-power Sector Cap in Million metric tons. | 2012 | Refer to Section 3.10.5 for details |
| CA – Bay Area AQMD | Reg 9, Rule 9 | NO _x | NO _x Emission Limits for gas turbines > 250 – 500 MM Btu/hr 0.43 lbs/MW/hr or 9 ppmv > 500 MM Btu/hr 0.15 lbs/MW/hr or 5 ppmv | 2006 | https://www.baaqmd.gov/~media/dotgov/files/rules/reg-9-rule-9-nitrogen-oxides-and-carbon-monoxide-from-stationary-gas-turbines/documents/rq0909.pdf?la=en&rev=fed388c23f264d6ebd5e6e40096bdf79 |
| | Reg 9, Rule 11 | NO _x | NO _x Emission Limits for Boilers with a Rated Heat Input Capacity Greater Than or Equal to 1.75 billion BTU/hour: 301.1 Gaseous Fuel: For gaseous fuel firing, nitrogen oxides (NO _x) shall not exceed 10 ppmv, dry at 3 percent oxygen; | 2000 | https://www.baaqmd.gov/~media/dotgov/files/rules/reg-9-rule-11-nitrogen-oxides-and-carbon-monoxide-from-utility-electric-power-generating-boilers/documents/rq0911.pdf?la=en&rev=cf79907f652d454c9b52a55ae3e95903 |
| | | NO _x | NO _x Emission Limits for Boilers with a Rated Heat Input Capacity Less Than 1.75 billion BTU/hour and Greater Than or Equal to 1.5 billion BTU/hour: Effective December 31, 2004, a person shall not operate an electric power generating steam boiler with a rated heat input less than 1.75 billion BTU/hour and greater than or equal to 1.5 billion BTU/hour unless the following conditions and emission limits are met: 303.1 Gaseous Fuel: For gaseous fuel firing, nitrogen oxides (NO _x) shall not exceed 25 ppmv, dry at 3 percent oxygen; | | |
| CO | CO Emission Limits for Boilers with a Rated Heat Input Capacity Greater Than or Equal to 250 million BTU/hour: | | | | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|-------------------------|--|-----------------|---|-----------------------|---|
| | | | 310.1 During steady state compliance source tests, carbon monoxide (CO) shall not exceed 400 ppmv, dry at 3 percent oxygen, based on the test methods referenced in Section 9-11-602; 310.2 During normal operation (CEMS compliance monitoring), carbon monoxide (CO) shall not exceed 1000 ppmv, dry at 3 percent oxygen, based on a clock hour average | | |
| CA – Colusa County APCD | Rule 251 | NO _x | Gas Turbines rated > 0.3 MW: 42 ppmv @ 15% O ₂ on a dry basis averaged over 3 hours, when gas fuel is used (Including natural, digester, and landfill) 65 ppmv @ 15% O ₂ on a dry basis averaged over 3 hours, when oil fuel is used (Including kerosene, jet fuel, and distillate, with the sulfur content of the oil less than 0.05% by weight) | 2002 | https://www.countyofcolusa.org/DocumentCenter/View/11866/Rule-251-Determination-of-RACT-for-the-Control-of-Oxides-of-Nitrogen-from-Stationary-Gas-Turbines |
| | Rule 252 | NO _x | Natural Gas-Fired, Rich-Burn Engines: 640 ppmv @ 15% O ₂ on a dry basis, for engines rated greater than 50 bhp but less than 300 bhp 90 ppmv @ 15% O ₂ on a dry basis, for engines rated greater than 300 bhp Natural Gas-Fired, Lean-Burn Engines: 740 ppmv @ 15% O ₂ on a dry basis, for engines rated greater than 50 bhp but less than 300 bhp 150 ppmv @ 15% O ₂ on a dry basis, for engines rated greater than 300 bhp | 2002 | https://www.countyofcolusa.org/DocumentCenter/View/11867/Rule-252-Stationary-Internal-Combustion-Engines |
| | | CO | Natural Gas-Fired engines rated greater than 50 bhp: 4500 ppmv @ 15% O ₂ on a dry basis | | |
| | Rule 262 | SO _x | 0.2 percent by volume (2000 ppm) collectively calculated as SO ₂ | 2002 | https://www.countyofcolusa.org/DocumentCenter/View/11869/Rule-262-Sulfur-Oxides Applies to both EGUs and non-EGUs. |
| CA – Eastern Kern APCD | Rule 425 | NO _x | Limits for stationary gas turbines >10MW: 9 ppm for gaseous fuel, 25 ppm for liquid fuel @ 15% O ₂ -Exception for Westinghouse W251B10 with an ATC prior to 1/1/1983: 25 ppm for gaseous fuel and 65 ppmv for liquid fuel | 2021 | http://kernair.org/Rule%20Book/4%20Prohibitions/425_Cogeneration_Gas_Turbine_Engines.pdf |
| | Rule 425.2 | NO _x | Limits for boilers, process heaters > 5 MMBTU/hr and more than 90,000 therms annual heat input: 30 ppmv (or 0.036 lb/MMBTU) when operated on gaseous fuel; 40 ppmv (or 0.052 lb/MMBTU) when operated on liquid fuel. -Exception for Union Iron Works CA B21841-68 and Combustion Engineering CA B35362-74 w an ATC prior to 1/1/1983: 70 ppmv for gaseous and 115 ppm for liquid | 2021 | http://kernair.org/Rule%20Book/4%20Prohibitions/425-2_Boilers_Steam_Generators_&_Process_Heaters.pdf |
| CA – Mojave Desert AQMD | Rule 1158 – Electric Power Generating Facilities | NO _x | Combustion turbines >10 MW with SCR: (9 * Efficiency/25) ppm @ 15% O ₂ for gaseous fuel and 25 * E/25 for liquid fuel CTs>10 MW w/o SCR: (15 * efficiency/25) ppm for gaseous fuel and (42 * E/25) for liquid fuel (efficiency cannot be less than 25 percent) | 1997 | https://www.mdaqmd.ca.gov/home/showpublisheddocument/1291/636341759986130000 |
| | Rule 431 | CO | Electric power boiler: | 2001 | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|------------------------------|-------------------------------------|-----------------|---|-----------------------|--|
| CA – Monterey Bay APCD | | | 400ppm (60-consecutive minute average) – during steady state compliance test 1000ppm (1 hour clock-hour average at 3% O ₂ on a dry basis) – during normal operations | | https://ww2.arb.ca.gov/sites/default/files/classic/technology-clearinghouse/rules/RuleID1660.pdf Applies to electric power boilers |
| | | Ammonia | Electric power boiler: 10ppm (60-consecutive minute average) – during steady state compliance test | | |
| | | NO _x | Electric power boiler (NO _x limits based on 1-hour average at 3% O ₂ on a dry basis): (1) If fired with natural gas: 90 ppm if >400 gross MW; 450 lb/hr if ≤ 400 gross MW; If fired with fuel oil: 225 ppm; (2) 10 ppm if fired with natural gas, or 25 ppm if fired with fuel oil. (3) May 1 through October 31, total NO _x from all boiler units shall not exceed an average of 9.64 tons per day; (4) All boilers combined at the power plant shall not exceed 0.3 lbs/MMBtu During fuel switching periods: • First 6 hours – applicable fuel oil limit; After 6 hours – limit is calculated using formula in Section 3.6.1 of this rule | | |
| CA- North Coast Unified APCD | Rule 104 | PM | Steam generating power plants: 0.10 lb/MMBtu, or any other specific applicable permit limitation, whichever is more restrictive | 1982 | https://www.ncuagmd.org/files/70b9a2edd/Rule+104.pdf |
| CA- Placer County APCD | Rule 233 – Boilers/Steam Generators | NO _x | Compliance limit (ppmv @ 12% CO ₂) for biomass boilers or steam generator: (a) Circulating fluidized bed (<500 MMBtu/hr) - 115 ppmv (averaged over 3 hrs) and 68 ppmv (averaged over 24 hrs). (b) Stoker (<500 MMBtu/hr) - 115 ppmv (averaged over 3 hrs) and 68 ppmv (averaged over 24 hrs). | 2012 | https://www.placerair.org/DocumentCenter/View/2205/Rule-233-PDF |
| | | CO | Compliance limit (ppmv @ 12% CO ₂) for biomass boilers or steam generator: (a) Circulating fluidized bed (<500 MMBtu/hr) - 400 ppmv (averaged over 3 hrs). (b) Stoker (<500 MMBtu/hr) - 1000 ppmv (averaged over 3 hrs). | | |
| | Rule 250 – Stationary Gas Turbines | NO _x | Compliance limit (ppm @ 15% O ₂ averaged over 1 hr over 4 consecutive 15-minute averages) for stationary gas turbines: (a) Gas (natural, digester, and landfill gases) – (iii) ≥ 10 MW – 9 ppm (b) Oil (kerosine, jet, and distillate) – (iii) ≥ 10 MW – 25 ppm | 2015 | https://www.placerair.org/DocumentCenter/View/2220/Rule-250-PDF |
| CA – Sacramento Metro AQMD | Rule 413 | NO _x | Natural gas fired combustion turbine - 15 ppm@15% O ₂ for units > 10 MW (no SCR) 9 ppm@15% O ₂ for units > 10 MW (w SCR) | 2005 | The rule does not require the use of SCR, but establishes a limit when units have installed them. |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|------------------------------|-------------|--|--|--|--|
| | | | | | https://ww2.arb.ca.gov/sites/default/files/classic/technology-clearinghouse/rules/RuleID3589.pdf |
| CA – San Diego APCD | Rule 69 | NOx | Applies to existing and new electrical generating steam boilers - Existing units subject to aggregate limit of 650 tons/yr on and after January 1, 2005 0.15 lb/MWh (natural gas), 0.40 lb/MWh (fuel oil) if unit not subject to aggregate limit | 1995 | https://ww2.arb.ca.gov/sites/default/files/classic/technology-clearinghouse/rules/RuleID3002.pdf |
| | Rule 69.3.1 | NOx | Natural gas fired combustion turbine - 15 x (E/25) ppm@15% O2 for units > 10 MW (no SCR) 9 x (E/25) ppm@15% O2 for units > 10 MW (w SCR) | 2021 | https://ww2.arb.ca.gov/sites/default/files/classic/technology-clearinghouse/rules/RuleID4832.pdf The (E/25) term represents an adjustment factor for thermal efficiency; a turbine with a thermal efficiency of < 25% is assigned an E value of 25 |
| CA – San Joaquin Valley APCD | Rule 4306 | NOx | Gas-fired Boilers >75 MMBtu/hr, 5 ppm @15% O2 or 0.0061 lb/MMBtu Liquid-fired Boilers>75 MMBtu/hr 40 ppm @15% O2 or 0.052 lb/MMBtu | 12/31/2023 | https://www.valleyair.org/rules/currnrules/r4306.pdf Applies to EGUs and non-EGUs; unclear if any EGUs subject |
| | | CO | 400 ppmv (gas and liquid fuels) | 12/31/2023 | |
| | Rule 4320 | NOX | Gas or liquid fuel-fired boilers >75 MMBtu/hr, 2.5 ppm @15% O2 OR pay a fee to avoid this limit | 12/31/2023 | https://www.valleyair.org/rules/currnrules/r4320.pdf , Applies to EGUs and non-EGUs; unclear if any EGUs subject |
| | Rule 4703 | NOX | Gas-fired combustion turbines >10 MW, combined cycle: 3 ppm for newer, rest 5 ppm @15% O2; Gas-fired simple cycle >10 MW: if permit limit below 200 hr/yr, then 25 ppm; if above 200 hrs then 5 ppm for older and 3 ppm for newer | ~2012 | https://www.valleyair.org/rules/currnrules/r4703.pdf Applies to EGUs and non-EGUs; likely existing EGUs subject to this rule |
| | Rule 4352 | NOX | Biomass or other solid fuel (except MSW): 65 ppm @3%O2; 30-day average MSW: 110 ppm 24-hr avg; 90 ppm 12 mo average | 1/1/2024 | https://www.valleyair.org/rules/currnrules/r4352_3.pdf Applies to EGUs and non-EGUs. |
| | | CO | 400 ppm @3%O2; 24-hr average | 1/1/2024 | |
| PM10 | | MSW: 0.04 lb/MMBtu or 0.02 gr/dscf @ 12%CO2 Biomass or other solid fuel (except MSW): 0.03 lb/MMBtu | 1/1/2024 | | |
| SOX | | MSW: 0.03 lb/MMBtu or 12 ppm @ 12%O2 12 mo average; 0.064 lb/MMBtu or 25 ppm @ 12% O224-hr avg Biomass or other solid fuel (except MSW): 0.02 lb/MMBtu 30-day average; 0.035 lb/MMBtu 24-hr average | 1/1/2024 | | |
| CA – South Coast AQMD | Rule 1135 | NOX | Boilers: 5 ppm@ 3%O2 Combined Cycle, and duct burner: 2 ppm @15%O2 Simple Cycle: 2.5 ppm -See specific requirements for city of Glendale prior to 1/1/2024 -Once through cooling units exempt if will retire by 12/31/2029 -Low use gas turbines installed prior to 11/2/2018 are exempted if annual capacity factor is less than 10%, 3yr rolling average AND less than 25% each calendar year, must retain existing applicable emissions limits | Currently 1/1/2024 (proposed amendment for 4/1/2024 to provide a few sources extra time) | https://www.agmd.gov/docs/default-source/rule-book/reg-xi/rule-1135.pdf?sfvrsn=4 Rule is for EGUs |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|--|--|--|-----------------------|---|
| | | | -low use exemption for boilers is <1% capacity factor on 3yr rolling basis and <2.5% each calendar year | | |
| | Rule 1110.2 | NOX | New Engines that are EGUs 0.070 lb/MW-hr or 2.5 ppm @15%O2 | 2019 | https://www.aqmd.gov/docs/default-source/rule-book/req-xi/rule-1110-2.pdf?sfvrsn=4 ; Rule for EGUs and non-EGUs, but has EGU specific requirements |
| | | VOC | New Engines that are EGUs 0.10 lb/MW-hr or 10 ppm | 2019 | |
| | | CO | New Engines that are EGUs 0.20 lb/MW-hr or 12 ppm | 2019 | |
| | 40 C.F.R. Part 60 | Hg | 2012 & 2013: 80% reduction of Hg content of fuel or 0.0174 lbs/GWh annual reduction for Pawnee Station 1 and Rawhide Station 101. 2014 through 2016: 80% reduction of Hg content of fuel or 0.0174 lbs/GWh annual reduction for all coal units > 25 MW 2017 onwards: 90% reduction of Hg content of fuel or 0.0087 lbs/GWh annual reduction for all coal units > 25 MW | 2012 | |
| Colorado | Clean Air, Clean Jobs Act | NO _x , SO ₂ , Hg | Retire Arapahoe 3 by 2014; Cherokee 1 & 2 by 2012, Cherokee 3 by 2017; Cameo 1 & 2; Valmont 5 by 2018; W N Clark 55 & 59 by 2015 Convert following units to natural gas: Arapahoe 4 by 2015; Cherokee 4 by 2018 Install SCRs in Hayden 1 & 2 by 2016; SCR + FGD in Pawnee 1 [already installed] | 2010 | Arapahoe 3, Cherokee 1-3, Cameo 1 & 2, Valmont 5, W N Clark 55 & 59 units have retired. Arapahoe 4 & Cherokee 4 units have retired. Hayden 1 has SCR, Hayden 2 retired. |
| | | Hg | Comanche Units 1, 2, and 3 Combined Hg Limit - 0.000013 lbs/MWh | 2012 | |
| | | NO _x | Craig Station Unit 1 and Unit 3 NO _x Limit - 0.28lbs/MMBtu | 2012 | |
| | | NO _x | Craig Station Unit 2 NO _x Limit - 0.08 lbs/MMBtu | 2012 | |
| | SB23-198 | CO ₂ | Directs Air Quality Control Commission to adopt rules to pursue reductions in greenhouse gasses from electric utilities by at least 47% by 2027 and 80% by 2030 relative to the 2005 levels. | 2027 | |
| Connecticut | Executive Order 19 and Regulations of Connecticut State Agencies (RCSA) section 22a-174-22e* | NO _x | 0.15 lbs/MMBtu rate limit for all fossil units > 15 MW (Non-ozone season only) <u>Ozone season (Pre June 1, 2023)</u> Daily average limits for EGU Boilers: Gas: 0.20 lbs/MMBtu (non-cyclone boilers) 0.30 lbs/MMBtu (cyclone boilers) Residual oil: 0.25 lbs/MMBtu (non-cyclone boilers) 0.43 lbs/MMbtu (cyclone boilers) Other oil: 0.20 lbs/MMBtu (non-cyclone boilers) 0.43 lbs/MMbtu (cyclone boilers) Coal: 0.28 lbs/MMBtu Daily average limits for simple cycle combustion turbines: Gas-fired: 55 ppm Oil-fired: 75ppm Daily average limits for combined cycle combustion turbines: Gas-fired: 42 ppm Oil-fired: 65 ppm | 2003 | Daily average limits shown are "Phase 1" limits, which began on June 1, 2018, and remain in effect until June 1, 2023, at which time more stringent limits take effect. *RCSA section 22a-174-22e was effective on 12/22/16 and replaced RCSA section 22a-174-22 (repealed on 6/1/19). As of July 1, 2021, Connecticut no longer has any coal EGUs. |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|---|-----------------|---|-----------------------|---|
| | | | <u>Ozone Season (June 1, 2023 onwards)</u> Daily average limits for EGU Boilers: Gas: 0.10 lbs/MMBtu Residual oil: 0.20 lbs/MMBtu Other oil: 0.10 lbs/MMBtu Coal: 0.12 lbs/MMBtu Daily average limits for simple cycle combustion turbines: Gas-fired: 40 ppm Oil-fired: 50 ppm Daily average limits for combined cycle combustion turbines: Gas-fired: 25 ppm Oil-fired: 42 ppm | | |
| | Executive Order 19, RCSA section 22a-174-19(a) & Connecticut General Statutes (CGS) section 22a-198 | SO ₂ | Combust fuel with a sulfur content < 3000 ppm; or Meet an average emission rate of < 0.33 lb SO ₂ /MMBtu for each calendar quarter; or Meet an average emission rate of < 0.3 lb SO ₂ /MMBtu for each calendar quarter if averaging the emissions from two or more units at a facility | | |
| | CGS section 22a-199 | Hg | 90% removal of Hg content of fuel or 0.6 lbs/TBtu quarterly basis for all coal-fired units | 2008 | As of July 1, 2021, Connecticut no longer has any coal EGUs. |
| | CGS section 22a-200a | CO ₂ | The state shall reduce the level of emissions of greenhouse gas: not later than January 1, 2040 to a level of zero percent from electricity supplied to electric customers in the state. | 2040 | |
| Delaware | Regulation 1148: Control of Stationary Combustion Turbine EGU Emissions | NO _x | 0.34 lb/MMBTU ozone season (88 ppmvd) for stationary, liquid fuel fired CT EGUs >1 MW 0.15 lb/MMBTU ozone season (42 ppmvd) for stationary, gas fuel fired CT EGUs >1 MW | 2009 | |
| | Regulation No. 1146: Electric Generating Unit (EGU) Multi-Pollutant Regulation | NO _x | 0.125 lbs/MMBtu rate limit of NO _x annually for all coal and residual-oil fired units > 25 MW (2012) | 2009 and 2012 | The following units have specific NO _x , SO ₂ , and Hg annual caps in MTons: Edge Moor 3 - NO _x : 0.773, SO ₂ : 1.391, Hg: 0.0000083 (2012), Hg: 0.0000033 (2013 onward) Edge Moor 4 - NO _x : 1.339, SO ₂ : 2.41 Hg: 0.0000144 (2012), Hg: 0.0000057 (2013 onward) Edge More 5 - NO _x : 1.348, SO ₂ : 2.427 (Retired) Indian River 3 – NO _x : 0.977, SO ₂ : 1.759, Hg: 0.0000105 (2012), Hg: 0.0000042 (2013 onward) (Retired) Indian River 4 - NO _x : 2.032, SO ₂ : 3.657 Hg: 0.0000219 (2012), Hg: 0.0000087 (2013 onward) (Retired) McKee Run 3 - NO _x : 0.244, SO ₂ : 0.439 (Note that both Indian River 3 and McKee Run 3 have retired; Indian River 3 in 2014 and McKee Run 3 in 2021.) |
| | | SO ₂ | 0.26 lbs/MMBtu annual rate limit for coal fired units > 25 MW (2012). Residual oil fired units have a limit on fuel oil sulfur content of 0.5% (2009). | | |
| | | Hg | 2012: 1.0 lb/TBTU Hg emissions rate limit or 80% reduction from baseline emissions rate for all coal units > 25 MW 2013 onwards: 0.60 lb/TBTU Hg emissions rate limit or 90% reduction from baseline emissions rate for all coal units > 25 MW | 2012 and 2013 | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--|---|---|--|---|--|
| | Regulation 1108: Distillate Fuel Oil rule | SO ₂ | 15ppm by weight sulfur in fuel limit for all distillate fuel oil sold or combusted in Delaware | 2016 | Fuel rule modeled through unit emission rates |
| Georgia | Multi-pollutant Control for Electric Utility Steam Generating Units | SCR, FGD, and Sorbent Injection Baghouse controls to be installed | The following plants must install controls: Bowen, Branch, Hammond, McDonough, Scherer, Wansley, and Yates | Implementation from 2008 through 2015, depending on plant and control type | |
| Illinois | Title 35, Section 217.706 | NO _x | 0.25 lbs/MMBtu summer season rate limit for all fossil units > 25 MW | 2003 | |
| | Title 35, Part 225, Subpart B 225.230 | Hg | 90% removal of Hg content of fuel; or a standard of 0.0080 lb Hg/GWh for sources at or above 25 MW; If facility commenced operation on or before December 31, 2008, start date for implementation must be July 1, 2009 | 2009 | Not Ameren Specific |
| | Title 35 Part 225 Subpart B 225.233 | NO _x | 0.11 lbs/MMBtu annual rate limit or a rate equivalent to 52% of base annual NO _x emissions (whichever is more stringent) and 0.11 lbs/MMBtu ozone season rate limit or a rate equivalent to 80% of base ozone season NO _x emissions (whichever is more stringent) for all coal steam units > 25 MW | 2012 | Not Ameren Specific |
| | | SO ₂ | 2015 onwards: 0.25 lbs/MMBtu annual rate limit for all coal steam units > 25 MW or a rate equivalent to 35% of the base SO ₂ emissions (whichever is more stringent) | 2015 | |
| | | Hg | 90% removal of Hg content of fuel or 0.008 lbs/GWh annual reduction for all coal units > 25 MW | 2015 | |
| | Title 35 Part 225 Subpart B 225.233 (MPS Ameren specific) | NO _x | 0.11 lbs/MMBtu annual rate limit and ozone season rate limit for Ameren coal steam units > 25 MW | 2012 | |
| | | SO ₂ | 2015 & 2016 onwards: 0.35 lbs/MMBtu annual rate limit for all Ameren coal steam units > 25 MW 2020 onwards: 0.23 lbs/MMBtu annual rate limit for all Ameren coal steam units > 25 MW System-wide mass emissions limit of 327,996 tons for 10/1/2013-12/31/2020 | 2015 (as modified by board orders 11/2013) | |
| | Title 35 Part 225 Subpart B 225.291-299 (Combined pollutant standard) | NO _x | 0.11 lbs/MMBtu group average annual and ozone season emission rates | 2012 | Applies to Midwest Generation's Coal-Fired Boilers as of 7/1/2006: Crawford (7 & 8), Fisk (19), Joliet (6, 7 & 8), Powerton (5 & 6), Waukegan (6, 7 & 8) and Will County (1, 2, 3 & 4) |
| | | SO ₂ | Group average annual emission rates of 0.44 lbs/MMBtu in 2013, 0.41 lbs/MMBtu in 2014, 0.38 lbs/MMBtu in 2015 and 2016, 0.15 lbs/MMBtu in 2017, 0.13 lbs/MMBtu in 2018 and 0.11 lbs/MMBtu in 2019 and after, and annual system wide mass SO ₂ emissions limits of no more than 57,000 tons in 2013, 54,000 tons in 2014, 39,000 tons in 2015, and 37,000 tons in 2016 | 2013 | |
| | | Hg | 90% removal of Hg content of fuel or 0.0080 lbs/GWh, compliance determined on a rolling 12-month basis | 2015 | |
| Illinois Pollution Control Board - Amendments To 35 Ill. Adm. Code 225.233, Multi-Pollutant Standard | NO _x – Ozone Season | The Board incorporates the amendments suggested by the IEPA in its testimony and comments. The IEPA proposed mass-based caps of 11,500 tons for NO _x for the ozone season. | 2019 | https://pcb.illinois.gov/documents/dsw/eb/Get/Document-100685 | |
| | NO _x | The Board incorporates the amendments suggested by the IEPA in its testimony and comments. The IEPA proposed mass-based caps of 19,000 tpy for NO _x . | 2019 | The amendments also require reduction of at least 2,000 megawatts (MW) of electric generation by coal fired EGUs in the MPS no later than | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|---|-----------------|---|-----------------------|--|
| | | SO ₂ | The Board incorporates the amendments suggested by the IEPA in its testimony and comments. The IEPA proposed mass-based caps of 34,500 tpy for SO ₂ . | 2019 | December 31, 2019 and adjust the allocation amounts for transfers, permanent shutdown, and temporary shutdown; and clarify the language of the rule. |
| | Public Act 102-0662 Sec. 9.15 | CO ₂ | Private Coal and Oil Units: Retire by 2030 Private Gas Units: Reduce emissions by 50% by 2035, Retire 2045 Public Coal Units: Reduce emissions by 45% by 2035 or retire a unit, Retire 2050 Public Gas Units: Retire by 2045 | 2021 | https://www.ilga.gov/legislation/publicacts/102/PDF/102-0662.pdf |
| | Public Act 102-0662 Sec.1.5 | CO ₂ | State policy to transition to 100 percent clean energy by 2050 | 2021 | https://www.ilga.gov/legislation/publicacts/102/PDF/102-0662.pdf |
| Indiana | A.B. Brown Generating Station Consent Order dated 1/11/2016 | SO ₂ | (A) When Unit 1 is operating alone: (i) 2152.2 lbs/hr, 1-hour average or 0.855 lbs/MMBtu 1-hour average; and (ii) 1831.6 lbs/hr, 24-hour average or 0.727 lbs/MMBtu 24-hour average; (B) When Units 1 & 2 are both in operation, both units shall not exceed the following combined emission rates: (i) 2152.2 lbs/hr, 1-hour average or 0.426 lbs/MMBtu 1-hour average; and (ii) 1831.6 lbs/hr, 24-hour average or 0.363 lbs/MMBtu 24-hour average; (C) When Unit 2 is operating alone: (i) 1745.7 lbs/hr, 1-hour average or 0.690 lbs/MMBtu 1-hour average; and (ii) 1485.59 lbs/hr, 24-hour average or 0.588 lbs/MMBtu 24-hour average; | 2016 | https://www.regulations.gov/document?D=EPA-R05-OAR-2016-0090-0005 |
| | Clifty Creek Generating Station Consent Order dated 2/1/2016 | SO ₂ | Units 1-6 - 2624.5 lbs SO ₂ /hr on a 720-hr rolling average | 2016 | |
| Kansas | NO _x Emission Reduction Rule, K.A.R. 28-19-713a. (Nearman Unit 1) | NO _x | Annual rate limit for Nearman Unit 1: 0.26 lbs/MMBtu | 2012 | |
| | NO _x Emission Reduction Rule, K.A.R. 28-19-713a. (Quindaro Unit 2) | NO _x | Annual rate limit for Quindaro Unit 1: 0.20 lbs/MMBtu | 2012 | Unit has retired. |
| Louisiana | Title 33 Part III - Chapter 22, Control of Nitrogen Oxides | NO _x | For units >= 80 MMBtu/hr, rate limit (Ozone season): Coal-fired: 0.21 lbs/MMBtu Oil-fired: 0.18 lbs/MMBtu All others (gas or liquid): 0.1 lbs/MMBtu | 2005 | Applicable for all units in Baton Rouge Nonattainment Area & Region of Influence. |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|---|-----------------|---|--|---|
| | | | Stationary Sources \geq 10 MMBtu/hr, rate limit (Ozone season): Oil-fired: 0.3 lbs/MMBtu Gas-fired: 0.2 lbs/MMBtu | | Willow Glenn, located in Iberville, obtained a permit that allows its gas-fired units to maintain a cap. These units are separately modeled. Willow Glenn units have retired. |
| | Title 33, Part III - Chapter 15, Emission Standards for Sulfur Dioxide | SO ₂ | 1.2 lbs/MMBtu for all single point sources that emit or have the potential to emit 5 tons or more of SO ₂ | 2005 | |
| Maine | Chapter 145 NO _x Control Program | NO _x | 0.22 lbs/MMBtu annual rate limit for all fossil fuel units > 25 MW built before 1995 with a heat input capacity < 750 MMBtu/hr. 0.15 lbs/MMBtu annual rate limit for all fossil fuel units > 25 MW built before 1995 with a heat input capacity > 750 MMBtu/hr. 0.20 lbs/MMBtu annual rate limit for all fossil fuel fired indirect heat exchangers, primary boilers, and resource recovery units with heat input capacity > 250 MMBtu/hr | 2005 | |
| | 38 MRSA Section 603-A Low Sulfur in Fuel Rule | SO ₂ | All fossil units require the use of 0.5% sulfur residual oil [0.52 lbs/MMBtu] 0.0015% sulfur for distillate | 2018 | Fuel rule modeled through unit emission rates |
| | Statue 585-B Title 38, Chapter 4: Protection and Improvement of Air | Hg | 25 lbs annual cap for any facility including EGUs (0.0000125 MTons) | 2010 | |
| Maryland | Maryland Healthy Air Act (COMAR 26.11.27) | NO _x | The annual NO _x tonnage limitations: 1/2009-12/31/2011 - 20.216 MTons 1/1/2012 onward - 16.667 MTons The ozone season NO _x tonnage limitations: 5/1/2009-9/30/2011 - 8.9 MTons 5/1/2012 onward - 7.337 MTons | 2009 | |
| | | SO ₂ | 1/1/2010-12/31/2012 - 48.618 MTons 1/1/2013 onward - 37.235 MTons | | |
| | | Hg | 1/1/2010-12/31/2012 - 80% removal of Hg content of fuel for 15 specific existing coal steam units 1/1/2013 onward - 90% removal of Hg content of fuel for 15 specific existing coal steam units | | |
| | COMAR 26.11.38 Control of NO _x Emissions from Coal-Fired Electric Generating Units | NO _x | Phase 1: requires all of the affected units to minimize NO _x emissions every day of the ozone season (5/1-9/30) by optimizing the pollution controls that are already in place. Phase 2: requires the owner or operator of units that have not installed SCR (H. A. Wagner Unit 2, C. P. Crane Units 1 and 2, Chalk Point Unit 2, and Dickerson Units 1, 2 and 3) to choose from the following: Option 1—By June 1, 2020, install and operate an SCR control system that can meet a NO _x emission rate of 0.09 lbs/MMBtu during the ozone season based on a 30-day rolling average; Option 2—By June 1, 2020, permanently retire the unit; Option 3—By June 1, 2020, switch fuel permanently from coal to natural gas and operate the unit on natural gas; or | Phase 1: May 1, 2015 Phase 2:2020 | Affected EGUs are all coal-fired EGUs owned by Raven Power Finance LLC (Raven Power) and NRG Energy, Inc. (NRG) in Maryland. Plants that are part of the Raven system include Brandon Shores Units 1 and 2, H. A. Wagner Units 2 and 3, and C. P. Crane Units 1 and 2. (Brandon Shores Units 1 and 2, H. A. Wagner Units 3 has SCR.) Plants that are part of the NRG system include: Morgantown Units 1 and 2, Chalk Point Units 1 and 2, and Dickerson Units 1, 2 and 3. |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|---------------|---|---|--|---|---|
| | | | <p>Option 4—By June 1, 2020, meet a system wide, daily NO_x tonnage cap of 21 tons per day for every day of the ozone season or meet a system wide NO_x emission rate of 0.13 lbs/MMBtu as a 24-hour block average. The rate and the cap in option 4 are consistent with levels assuming SCR controls on all units. If option 4 is selected, deeper reductions starting in May 2016, 2018 and 2020 must also be achieved.</p> <p>2016—Meet a 30-day system wide rolling average NO_x emission rate of 0.13 lbs/MMBtu during the ozone season.</p> <p>2018—Meet a 30-day system wide rolling average NO_x emission rate of 0.11 lbs/MMBtu during the ozone season.</p> <p>2020—Meet a 30-day system wide rolling average NO_x emission rate of 0.09 lbs/MMBtu during the ozone season.</p> <p>Without option 4, the allowable 30-day system wide rolling average NO_x emission rate is 0.15 lbs/MMBtu during the ozone season.</p> <p>Option 4 also includes provisions to ensure that the reliability of the electrical system is maintained.</p> <p>Affected EGUs equipped with a fluidized bed combustors (AES Warrior Run) shall meet a 24-hr block average annual NO_x emission rate of 0.10 lbs/MMBtu</p> | | <p>The Crane units were sold on or around 2/16/2016 and are no longer part of the Raven System.</p> <p>AES Warrior Run</p> |
| Massachusetts | 310 CMR 7.19 NO _x RACT II | NO _x | <p>Large Boilers- 100 MMBtu or greater: Coal tangential and face fired 0.12 lbs/MMBtu.</p> <p>Greater than 250 MMBtu oil tangential or face fired: 0.15 lbs/MMBtu</p> <p>Tangential gas 0.08 lbs/MMBtu</p> <p>Boilers between 100 MMBtu and less than 250 MMBtu burning oil or oil and gas: 0.15 lbs/MMBtu or for Boilers burning only gas 0.06 lbs/MMBtu</p> <p>Combustion Turbines: Combined cycle turbines -25 ppmvd when firing gas, 42 ppmvd when firing oil.</p> <p>Simple Cycle turbines- 40 ppmvd when firing gas, 50 ppmvd firing oil</p> <p>2020 RICE- rich burn gas fired, and lean burn gas fired 1.5 grams per bhp-hr. Lean burn oil fired or dual fuel, 2.3 grams per bhp-hr.</p> | 2020 | <p>Boilers and turbines with an annual capacity factor less than 10% averaged over the most recent three-year consecutive period not subject to the new more stringent emission standards.</p> <p>Engines that operated less than 1,000 hours during any consecutive 12-month period not subject to the more stringent emission standards</p> |
| | | CO | <p>Boilers: 200 ppmvd</p> <p>Turbines: Combined cycle 50 ppmvd, simple cycle 100 ppmvd</p> <p>Engines: no change</p> | 2020 | |
| | 310 CMR 7.29 | NO _x | 1.5 lbs/MWh annual GPS for Brayton Point, Mystic Generating Station, Mount Tom, Canal, and Salem Harbor | 2006 | Brayton Point, Salem Harbor, MT Tom, and Mystic Generating Station have permanently retired. |
| | | SO ₂ | 3.0 lbs/MWh annual GPS for Brayton Point, Mystic Generating Station, Mount Tom, Canal, and Salem Harbor | | |
| | Hg | <p>2012: 85% removal of Hg content of fuel or 0.0000025 lbs/MWh annual GPS for Brayton Point, Mystic Generating Station, Mount Tom, Canal, and Salem Harbor</p> <p>2013 onwards: 95% removal of Hg content of fuel or 0.0000025 lbs/MWh annual GPS for Brayton Point, Mystic Generating Station, Mount Tom, Canal, and Salem Harbor</p> | | | |
| 310 CMR 7.05 | SO ₂ | Sulfur in Fuel Oil Rule requires the use of 0.5% sulfur residual oil [0.52 lbs/MMBtu] after July 1, 2018 for units greater than 250 MMBtu energy | 2014 | Fuel rule modeled through unit emission rates | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|---------------|---|-----------------|--|-----------------------|--|
| | | Sulfur in fuel | input; all residual oil units except for those located in the Berkshire APCD are affected. Distillate oil- 0.05% (500 ppm) July 1, 2014-June 30, 2018 Distillate oil 0.0015% (15 ppm) on and after July 1, 2018 | 2014 | |
| | 310 CMR 7.74: Reducing CO2 Emissions from Electricity Generating Facilities | CO ₂ | The regulation sets the existing facility aggregate CO ₂ emissions limit, and new facility aggregate CO ₂ emissions limit as the following: Total Aggregate CO ₂ Emissions Limits - The total aggregate CO ₂ emissions limit for 2018 and 2019 are 9,149,979 metric tons of CO ₂ and 8,731,175 metric tons of CO ₂ respectively. The total aggregate CO ₂ emissions limit declines by 223,876 metric tons each year thereafter until it reaches 8,507,299 metric tons of CO ₂ in 2020 and 1,791,019 metric tons of CO ₂ in 2050. | 2018 | https://www.mass.gov/doc/fact-sheet-massdep-electricity-sector-regulations/download |
| | MGL c.21N Sections 3(b) and 4(h) | GHGs | A 2050 statewide emissions limit that achieves at least net zero statewide greenhouse gas emissions; provided, however, that in no event shall the level of emissions in 2050 be higher than a level 85 percent below the 1990 level." and "The interim 2030 statewide greenhouse gas emissions limit shall be at least 50 percent below the 1990 level, and the interim 2040 statewide greenhouse gas emissions limit shall be at least 75 percent below the 1990 level. | 2030 | https://malegislature.gov/Laws/GeneralLaws/PartI/TitleII/Chapter21N/Section3 https://malegislature.gov/Laws/GeneralLaws/PartI/TitleII/Chapter21N/Section4 |
| Michigan | Part 18 Rules – R 336.1801 (2) (a) | NO _x | For all fossil units > 25 MW, and annual PTE of NO _x >25 tons, 0.25 lbs/MMBtu ozone season rate, OR 65% NO _x reductions from 1990 levels | 2004 | |
| | Part 4 Rules – R 336.1401 | SO ₂ | SO ₂ ppmvd rates in 50% excess air for units in Wayne county - Pulverized coal: 550; Other coal: 420; Distillate oil Nos. 1 & 2: 120; Used oil: 300; Crude and Heavy oil: 400 For all other units, with 0-500,000 lbs Steam per Hour Plant Capacity: 2.5 SO ₂ ppmvd rates at 50% excess air for solid fuel is 890 and for liquid fuel is 630; the pounds of SO ₂ per MMBtu of heat input for solid fuel is 2.5 and 1.67 for liquid fuel with >500,000 lbs Steam per Hour Plant Capacity: 1.67 SO ₂ ppmvd rates at 50% excess air for solid fuel is 590 and for liquid fuel is 420; the pounds of SO ₂ per MMBtu of heat input for solid fuel is 1.67 and 1.11 for liquid fuel | 2012 | Not modeled in IPM as limits are within SIP rates |
| | Part 15. Emission Limitations and Prohibitions - Mercury | Hg | 90% removal of Hg content of fuel annually for all coal units > 25 MW An affected EGU is defined in Part 15 as unit with a nameplate capacity of greater than 25 MW producing electricity for sale. An out-put based emission standard of 0.008 lb of Hg per gigawatts hour on a 12-month rolling average as determined at the end of each calendar month | 2015 | |
| Minnesota | Minnesota Hg Emission Reduction Act | Hg | 90% removal of Hg content of fuel annually for all coal facilities > 500 MW combined; Dry scrubbed units must implement by December 31, 2010; Wet scrubbed units must implement by December 31, 2014. | 2006 | |
| Montana | Montana Mercury Rule Adopted 10/16/06 | Hg | 0.90 lbs/TBtu annual rate limit for all non-lignite coal units 1.50 lbs/TBtu annual rate limit for all lignite coal units | 2010 | |
| New Hampshire | RSA 125-O: 11-18 | Hg | 80% reduction of aggregated Hg content of the coal burned at the facilities for Merrimack Units 1 & 2 and Schiller Units 4, & 6 | 2012 | Schiller Unit 5 is no longer subject because PSNH installed a new unit. 80% reduction from baseline. |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|---|-----------------|---|---|--|
| | | | | | Baseline = 268 lbs/yr. 80% reduction = 53.6 lbs/yr |
| | Env-A 1300, NOx RACT | NOx | 24-hour limits: Merrimack Units 1 & 2 - 0.22 lbs NO _x /MMBtu | 2018 | There are additional limits of 4.0 and 11.5 tons per day on any calendar day during which a startup or shutdown occurs. |
| | | | 24-hour limits: Newington Unit 1 – 0.25 lbs NO _x /MMBtu | 1994 | Originally Env-A 1211, but this limit has been in place since 1994 |
| | Env-A 3200, NOx Budget Trading Program | NOx | 2.40 MTons summer cap for all fossil steam units > 250 MMBtu/hr operated at any time in 1990 and all new units > 15 MW | 2006 | Applies to Merrimack Units 1 & 2, Merrimack Combustion Turbines 1 & 2, Schiller Units 4 & 6, Schiller Combustion Turbine 1, Newington Unit 1, White Lake Turbine, Lost Nation Turbine, Granite Ridge Energy, and Newington Energy. |
| | Env-A 2900, Multiple Pollutant Annual Budget Trading and Banking Program | NO _x | Emission Caps: 3.64 MTons annual cap for Merrimack Units 1 & 2, Newington Unit 1, and Schiller Units 4 through 6 | 2004 | Schiller Unit 5 is no longer subject because PSNH installed a new unit. |
| | | SO ₂ | 7.29 MTons annual cap for Merrimack Units 1 & 2, Newington Unit 1, and Schiller Units 4 through 6 | | |
| | Env -A 2300 - Mitigation of Regional Haze | SO ₂ | 94% SO ₂ control from Merrimack Units 1 & 2 combined 30-boiler operating day rolling average; 0.50 lb SO ₂ /MMBtu 30 day rolling average at Newington Unit 1 | 2013 | |
| New Jersey | N.J. A. C. Title 7, Chapter 27, Subchapter 9, Low Sulfur Fuel Rule | SO ₂ | 15 ppm for No. 2 and lighter fuel 2,500 ppm for No. 4 fuel | July 1 2016 (No. 2. And lighter), July1,2014 (No. 4) | |
| | N.J. A. C. Title 7, Chapter 27, Subchapter 10.2 | SO ₂ | 0.15 (30 day rolling average) lbs/MMBtu and 0.25 (24-hour) lbs/MMBtu | 2012 | |
| | N.J.A.C. 7:27-27.5, 27.6, 27.7, and 27.8 | Hg | 90% removal of Hg content of fuel annually for all coal-fired units or <= 3.0 mg/MWh (net) 95% removal of Hg content of fuel annually for all MSW incinerator units or <= 28 ug/dscm | 2007 | |
| | N.J. A. C. Title 7, Chapter 27, Subchapter 19, Table 3 | NO _x | 1.50 lbs/MWh for Boilers firing coal and serving electric generating units 2.00 lbs/MWh for Boilers firing heavier than No. 2 fuel oil and serving electric generating units 1.00 lbs/MWh for Boilers firing No. 2 and lighter fuel oil and serving electric generating units 1.00 lbs/MWh for Boilers firing gas only and serving electric generating units | 05/01/2015 | Operative on and after May 1, 2015 |
| | N.J. A. C. Title 7, Chapter 27, Subchapter 19, Table 7; High Electricity demand Day (HEDD) unit | NO _x | 1.00 lbs/MWh for gas-burning simple cycle combustion turbine units 1.60 lbs/MWh for oil-burning simple cycle combustion turbine units 0.75 lbs/MWh for gas-burning combined cycle CT or regenerative cycle CT units 1.20 lbs/MWh for oil-burning combined cycle CT or regenerative cycle CT units On and after May 1, 2015, the owner or operator of a stationary combustion turbine that is a HEDD unit or a stationary combustion turbine that is capable of generating 15 MW or more and that commenced operation on or after May 1, 2005 shall comply with limits outlines “in Table 7 during | 2007 | Not modeled as these rates are applicable only during HEDD. |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|--|--|--|-----------------------|---|
| | | | operation on high electricity demand days, regardless of the fuel combusted, unless combusting gaseous fuel is not possible due to gas curtailment." | | |
| New Jersey | N.J. A. C. Title 7, Chapter 27F, Control and Prohibition of Carbon Dioxide Emissions | CO2 (Co-benefits of NOx, SO2, PM and HAPs) | 1,700 lbs of CO2/MWh of gross energy output on or before 6/1/2024 1,300 lb of CO2/MWh of gross energy output on or before 6/1/2027 1,000 lb of CO2/MWh of gross energy output on or before 6/1/2035 | 2023 | N.J.A.C. 7:27F-2.5(d) available at https://dep.nj.gov/wp-content/uploads/rules/rules/njac7-27f.pdf |
| New York | Part 222 | NOx | Distributed Generation Sources This rule applies to owners and operators of distributed generation sources classified as economic dispatch sources located in the New York City metropolitan area with a maximum output rating of 200 horsepower or greater where the potential to emit NOx at a facility is less than 25 tons per year. Beginning May 1, 2021, the first phase will be implemented. combustion turbines, compression ignition engines and lean-burn natural gas-fired engines must be of model year 2000 or newer OR must have a NOx emission rate less than or equal to 2.96 pounds per megawatt-hour as certified in writing by a professional engineer. Also, effective May 1, 2021, rich-burn natural gas-fired engines must be equipped with three-way catalyst emission controls (<i>a control technology that reduces NOx, VOC and CO emissions from rich burn engines.</i>) Beginning May 1, 2025, the second phase will be implemented. For combustion turbines firing natural gas, presumptive NO _x emission limits are reduced to 25 parts per million on a dry volume basis corrected to 15 percent oxygen. For combustion turbines firing oil, presumptive NO _x emission limits are reduced to 42 parts per million on a dry volume basis corrected to 15 percent oxygen. For spark ignition engines firing natural gas, presumptive NO _x emission limits are reduced to 1.0 grams per brake horsepower-hour. For compression-ignition engines firing distillate oil with nameplate rating less than 750 hp, presumptive NO _x emission limits are reduced to 0.30 grams per brake horsepower-hour. For compression-ignition engines firing distillate oil with nameplate rating greater than or equal to 750 hp, presumptive NO _x emission limits are reduced to 0.50 grams per brake horsepower-hour. | 2021 and 2025 | https://govt.westlaw.com/nycrr/Browse/Home/NewYork/NewYorkCodesRulesandRegulations?guid=I06948fa0c87f11e68e78e7873f673e4d&originationContext=documenttoc&transitionType=Default&contextData=(sc.Default) |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|--|-----------------|--|-----------------------|---|
| New York | Subpart 227-3 | NO _x | <p>Ozone Season NO_x Emission Limits for Simple Cycle and Regenerative Combustion Turbines:</p> <p>For SCCTs with a nameplate capacity of 15 megawatts or greater that inject power into the transmission or distribution systems:</p> <p>Beginning 5/1/2023, the first phase of NO_x emission limits will be implemented during the ozone season and SCCTs will be limited to averaging with other SCCTs, storage or renewable energy resources. The first phase of emission limits will be:</p> <p>All SCCTs: 100 ppmvd</p> <p>Beginning 5/1/2025, the second and final phase of NO_x emission limits will be implemented during the ozone season as follows:</p> <p>Gaseous fuels: 25 ppmvd Distillate oil or other liquid fuel: 42 ppmvd</p> <p>Notes: Parts per million on a dry volume basis at fifteen percent oxygen.</p> | 2023 and 2025 | https://www.dec.ny.gov/regulations/116175.html |
| New York | Part 225 | SO ₂ | <p>Owners and/or operators of any stationary combustion installation that fires solid fuels are limited to the firing of solid fuel with a sulfur content listed in the table below on or after July 1, 2014:</p> <p>Solid fuel (pounds of sulfur/millionBtu) New York City: 0.2 MAX. Nassau, Rockland and Westchester Counties: 0.2 MAX. Suffolk County: Towns of Babylon, Brookhaven, Huntington, Islip, and Smith Town: 0.6 MAX. Erie and Niagara Counties: 1.7 MAX, 1.4 AVG. Remainder of State: 2.5 MAX, 1.9 AVG</p> <p>Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014.</p> <p>Owners and/or operators of any stationary combustion installation that fires distillate oil including number two heating oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016.</p> | 2014 and 2016 | |
| | Part 243 | NO _x | 5,135 tons NO _x Ozone season budget for fossil fuel units greater than 25 MW. | 2017 | |
| | Part 244 | NO _x | 16,081 tons NO _x annual budget for fossil fuel units greater than 25 MW. | 2017 | |
| | Part 245 | SO ₂ | 27,556 tons SO ₂ annual budget for fossil fuel units greater than 25MW | 2017 | |
| | Part 237 | NO _x | 39.91 MTons non-ozone season cap for fossil fuel units > 25 MW | 2004 | Repealed |
| | Part 238 | SO ₂ | 131.36 MTons annual cap for fossil fuel units > 25 MW | 2005 | Repealed |
| | Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units | Hg | 786 lbs annual cap through 2014 for all coal fired boiler or CT units >25 MW after Nov. 15, 1990. For facilities identified in Table 1 of Part 246 and includes 40 lbs set aside. | 2010 | https://govt.westlaw.com/nycrr/Browse/Home/NewYork/NewYorkCodesRulesandRegulations?guid=lc3039690b5 |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|---|--|-----------------|--|-----------------------|--|
| | | | 0.60 lbs/TBtu annual rate limit for all coal units > 25 MW developed after November 15, 1990 for new units and existing facilities – effective January 1, 2015. | | a011dda0a4e17826ebc834&originatio nContext=documentoc&transitionTyp e=Default&contextData=%28sc.Default It%29 |
| | Subpart 227-2 Reasonably Available Control Technology (RACT) For Major Facilities of Oxides Of Nitrogen (NO _x) | NO _x | Annual rate for very large boilers >250 MMBtu/hr on or after July 1, 2014 Gas only, tangential & wall fired: 0.08 lbs/MMBtu Gas/oil tangential & wall fired: 0.15 lbs/MMBtu; cyclone: 0.2 lbs/MMBtu Coal Wet Bottom, tangential & wall fired: 0.12 lbs/MMBtu; cyclone: 0.2 lbs/MMBtu Coal Dry Bottom, tangential & wall fired: 0.12 lbs/MMBtu; stokers: 0.08 lbs/MMBtu | 2004 | |
| Annual rate for large boilers between 100 and 250 MMBtu/hr on or after July 1, 2014; Gas Only: 0.06 lbs/MMBtu Gas/Oil: 0.15 lbs/MMBtu Pulverized Coal: 0.20 lbs/MMBtu Coal (Overfeed Stoker/FBC): 0.8 lbs/MMBtu | | | | | |
| Annual rate for mid-size boilers between 25 and 100 MMBtu/hr on or after July 1, 2014; Gas Only: 0.05 lbs/MMBtu Distillate Oil/Gas: 0.08 lbs/MMBtu Residual Oil/Gas: 0.20 lbs/MMBtu | | | | | |
| Combined cycle and cogeneration combustion turbines must have an approved case by case RACT determination from the Department by July 1, 2014. Simple cycle combustions turbines are required to meet 50 ppm on natural gas and 100 ppm on distillate oil. | | | Compliance with these emission limits must be determined with a one-hour average during the ozone season and a 30-day average during the non-ozone season unless the owner or operator chooses to use a CEMS under the provisions of section 227-2.6(b) of this Subpart. | | |
| | | | | | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|---|-----------------|--|-----------------------|---|
| | | | <p>Stationary internal combustion engines having a maximum mechanical output => 200 brake horsepower in a severe ozone nonattainment area or having a maximum mechanical output rating =>400 brake horsepower outside a severe ozone nonattainment area must comply with one of the emission limits in paragraph (1), (2), or (3) of this subdivision or a case-by-case RACT determination made pursuant to paragraph (4) of this subdivision, as applicable:</p> <p>(1) For internal combustion engines fired solely with natural gas: 1.5 grams per brake horsepower-hour.</p> <p>(2) For internal combustion engines fired with landfill gas or digester gas (solely or in combination with natural gas): 2.0 grams per brake horsepower-hour.</p> <p>(3) For internal combustion engine fired with distillate oil (solely or in combination with other fuels): 2.3 grams per brake horsepower-hour.</p> <p>(4) For stationary internal combustion engines fired primarily with fuels not listed above, the owner or operator must submit a proposal for RACT to be implemented that includes descriptions of:</p> <p>(i) the available NO_x control technologies, the projected effectiveness of the technologies considered, and the costs for installation and operation for each of the technologies; and (ii) the technology and the appropriate emission limit selected as RACT considering the costs for installation and operation of the technology.</p> <p>(5) Any stationary internal combustion engine may rely on an emission limit that reflects a 90 percent or greater NO_x reduction from the engine's actual 1990 baseline emissions, if such emissions baseline exists.</p> <p>(6) Emergency power generating stationary internal combustion engines, and engine test cells at engine manufacturing facilities that are used for either research and development purposes, reliability testing, or quality assurance performance testing are exempt from the requirements of this subdivision.</p> | | |
| | Part 242 CO ₂ Budget Trading Program | CO ₂ | <p>Any unit that, at any time on or after January 1, 2005, serves an electricity generator with a nameplate capacity equal to or greater than 25 MWe shall be a CO₂ budget unit, and any source that includes one or more such units shall be a CO₂ budget source, subject to the requirements of this Part.</p> <p>(a) The CO₂ Budget Trading Program base budget is 35,228,822 tons, for the 2019 allocation year.</p> <p>(b) The CO₂ Budget Trading Program base budget is 30,435,778 tons, for the 2020 allocation year.</p> <p>(c) The CO₂ Budget Trading Program base budget is 29,056,270 tons, for the 2021 allocation year.</p> <p>(d) The CO₂ Budget Trading Program base budget is 28,175,777 tons for the 2022 allocation year.</p> <p>(e) The CO₂ Budget Trading Program base budget is 27,295,284 tons for the 2023 allocation year.</p> <p>(f) The CO₂ Budget Trading Program base budget is 26,414,791 tons, for the 2024 allocation year.</p> <p>(g) The CO₂ Budget Trading Program base budget is 25,534,298 tons, for the 2025 allocation year.</p> <p>(h) The CO₂ Budget Trading Program base budget is 24,653,805 tons, for the 2026 allocation year.</p> <p>(i) The CO₂ Budget Trading Program base budget is 23,773,312 tons, for the 2027 allocation year.</p> | 2020 | <p>Full Rule Link: https://govt.westlaw.com/nycrr/Browse/Home/NewYork/NewYorkCodesRulesandRegulations?guid=Iafc5f680d5e011ddb477e8e3dda68a63&originatonContext=documenttoc&transitionType=Default&contextData=%28sc.Default%29&bhcp=1</p> <p>Part 242-2 CO₂ Allowance Allocations Link: https://govt.westlaw.com/nycrr/Browse/Home/NewYork/NewYorkCodesRulesandRegulations?guid=Idb97d060db11dd9768bd0e013d693a&originatonContext=documenttoc&transitionType=Default&contextData=%28sc.Default%29</p> |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|----------------|---|-----------------|---|-----------------------|--|
| | | | (j) The CO ₂ Budget Trading Program base budget is 22,892,819 tons, for the 2028 allocation year. (k) The CO ₂ Budget Trading Program base budget is 22,012,326 tons, for the 2029 allocation year. (l) The CO ₂ Budget Trading Program base budget is 21,131,833 tons, for the 2030 allocation year and each succeeding allocation year. | | |
| | Part 251 CO ₂ Performance Standards for Major Electric Generating Facilities | CO ₂ | Owners and operators of major electric generating facilities (those which sell power to the grid and utilize boilers, combustion turbines, waste to energy sources, and/or stationary internal combustion engines to produce electricity with a generating capacity of at least 25 MW) that provide more than 10 percent of their annual electric output to the grid must meet CO ₂ emission rates. For New Sources and modified existing sources that are boilers permitted to fire at greater than 70% fossil fuel, combined cycle combustion turbines, or stationary internal combustion engines that fire only gaseous fuels are required to meet an emission rate of 925 lbs. of CO ₂ per MWh gross electrical output or 160 lbs. of CO ₂ per million BTU of input For new or modified simple cycle turbines or stationary internal combustion engines that fire either liquid and gaseous fuel simultaneously are required to meet an emission rate of 1450 lbs. of CO ₂ per MW hour gross electrical output or 160 lbs. of CO ₂ per million BYU of input Non-Modified Existing sources are required to meet an emission rate of 1800 lbs. of CO ₂ per MW gross electrical output or 180 lbs. of CO ₂ per million BTU of input for each fossil fuel combusted | 2020 | |
| North Carolina | NC Clean Smokestacks Act: Statute 143-215.107D | NO _x | 25 MTons annual cap for Progress Energy coal plants > 25 MW and 31 MTons annual cap for Duke Energy coal plants > 25 MW | 2007 | |
| | | SO ₂ | 2012: 100 MTons annual cap for Progress Energy coal plants > 25 MW and 150 MTons annual cap for Duke Energy coal plants > 25 MW 2013 onwards: 50 MTons annual cap for Progress Energy coal plants > 25 MW and 80 MTons annual cap for Duke Energy coal plants > 25 MW | 2009 | |
| | NCAC 02D .2500 – Mercury Rules for Electric Generators | Hg | Coal-fired electric steam >25 MW to comply with the mercury emission caps of 1.133 tons (36,256 ounces) per year between 2010 and 2017 inclusive and 0.447 tons (14,304 ounces) per year for 2018 and thereafter | 2010 | NC rule expired effective February 1, 2016, because MATS rule was vacated https://www.deq.nc.gov/about/division/s/air-quality/air-quality-planning/air-quality-rules-regulations/rules/section-2500-mercury-rules-electric-generators-expired |
| | 15A NCAC 02D .2511 | Hg | Duke Energy and Progress Energy Hg control plans submitted on January 1, 2013 and are awaiting approval. All control technologies and limitations must be implemented by December 31, 2017. | 2017 | Expired effective February 1, 2016, because MATS rule was vacated |
| | North Carolina <u>SL 2021-165 (House Bill 951)</u> | CO ₂ | Requires NC Utilities Commission to achieve 70% carbon emissions reduction from 2005 levels by 2030 and achieve carbon neutrality by 2050. | 2030 | Duke Energy is expected to release in Sept. 2023 its Integrated Resource Plan supporting implementation of SL 2021-165. |
| Oregon | Oregon Administrative Rules, Chapter 345, Division 24 | CO ₂ | 675 lbs/MWh annual rate limit for new combustion turbines burning natural gas with a CF >75% and all new non-base load plants (with a CE <= 75%) emitting CO ₂ | 1997 | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|---|-----------------|---|-----------------------|---|
| | Oregon Utility Mercury Rule - Existing Units | Hg | 90% removal of Hg content of fuel reduction or 0.6 lbs/TBtu limitation for all existing coal units >25 MW | 2012 | No existing coal units in Oregon. |
| | Oregon Utility Mercury Rule - Potential Units | Hg | 25 lbs limit for all potential coal units > 25 MW | 2009 | |
| | Oregon House Bill 2021 | CO ₂ | Retail electricity providers are to reduce greenhouse gas emissions associated with electricity sold to consumers to 80% below baseline emission levels by 2030, 90% below baseline levels by 2035 and 100% below baseline levels by 2040. No new emitting fossil builds. | 2030 | |
| Pennsylvania | PA RACT | NO _x | For SCR equipped coal units, the NO _x emission rate limit (lb/MMBtu) will be based on a 30-day rolling average and will apply at all times even during operations when exhaust temperatures are too low for the SCR to operate or operate optimally. For facilities with multiple units, the rate limit will be based on the weighted average rate by the best performing unit. For these units a unit-specific daily mass emission limit is also placed where the limit is the product of the facility wide 30-day rolling average and each unit's heat input maximum permitted rate capacity. | 2022 | |
| Texas | Senate Bill 7 Chapter 101 | SO ₂ | 273.95 Mtons cap of SO ₂ allowances allocated annually for all grandfathered units built before 1971 and electing units in East Texas Region | 2003 | |
| | | NO _x | Annual cap for all grandfathered units built before 1971 in Mtons: 84.50 in East Texas, 18.10 in West Texas, 1.06 in El Paso Region | | |
| | Chapter 117 | NO _x | <p>East and Central Texas annual rate limits in lbs/MMBtu for units that came online before 1996: Gas fired units: 0.14 lbs/MMBtu heat input Coal fired units: 0.165 lbs/MMBtu heat input Stationary gas turbines: 0.14 lbs/MMBtu heat input System cap: tons per year according to §117.3020(c)</p> <p>Dallas-Fort Worth Eight-Hour Ozone Nonattainment Area limits for utility boilers, auxiliary steam boilers, and stationary gas turbines used in an electric power generating system: Utility boilers: • Large utility systems: <input type="checkbox"/> 0.033 lb/MMBtu heat input rolling 24-hour (March - October) and rolling 30-day (November, December, January, February); <input type="checkbox"/> 0.033 lb/MMBtu heat input, system-wide heat input weighted average rolling 168-hour • Small utility systems: 0.06 lb/MMBtu heat input rolling 24-hour (March - October) and rolling 30-day (November, December, January, February) • 0.50 lb/MWh annual output</p> <p>Auxiliary steam boilers: • Natural gas or combination of natural gas and waste oil: 0.26 lb/MMBtu heat input rolling 24-hour and 0.20 lb/MMBtu heat input rolling 30-day • Fuel oil: 0.30 lb/MMBtu heat input rolling 24-hour • Mixture of natural gas and fuel oil: heat input weighted average of applicable (above) specifications rolling 24-hour according to §117.1310(a)(2)(C) • Or applicable NSPS NO_x emission limit in Subparts D, Db, or Dc</p> | 2007 | <p>Units are also allowed to comply by reducing the same amount of NO_x on a monthly basis using a system cap or by purchasing credits.</p> <p>East and Central Texas, Dallas/Fort Worth Area, Beaumont-Port Arthur region units are assumed to be in compliance based on their reported 2011 ETS rates. The regulations for these regions are not modeled.</p> |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|--|-----------------|--|-----------------------|-------|
| | | | <p>Stationary gas turbines:</p> <ul style="list-style-type: none"> • Non-peaking units \geq 30 MW (annual MWh \geq 2500 hours X unit MW rating): <ul style="list-style-type: none"> <input type="checkbox"/> Natural gas: 42 ppmv (15% O₂, dry) block one-hour <input type="checkbox"/> Fuel oil: 65 ppmv (15% O₂, dry) block one-hour • Peaking units (annual MWh < 2500 hours X unit MW rating): <ul style="list-style-type: none"> <input type="checkbox"/> Natural gas: 0.20 lb/MMBtu heat input block one-hour <input type="checkbox"/> Fuel oil: 0.30 lb/MMBtu heat input block one-hour <p>Houston-Galveston-Brazoria Eight-Hour Ozone Nonattainment Area annual Mass Emissions Cap and Trade (MECT) Program for EGUs and non-EGUs. EGUs include utility boilers, auxiliary steam boilers, stationary gas turbines, and duct burners used in turbine exhaust ducts used in an electric power generating system:</p> <p>39.99 MTons NOx allowances allocated annually to all MECT sources (EGUs and Non-EGUs combined); 17.57 MTons NOx allowances allocated annually to all MECT sources (EGUs)</p> <p>Beaumont-Port Arthur Area limits for utility boilers, auxiliary steam boilers, and stationary gas turbines used in an electric power generating system:</p> <p>Utility boilers:</p> <ul style="list-style-type: none"> • 0.10 lbs/MMBtu heat input daily average • System cap in lb/day based on rolling 30-day cap and maximum daily cap according to §117.1020(c)(1)-(2) <p>Auxiliary steam boilers:</p> <ul style="list-style-type: none"> • Natural gas or combination of natural gas and waste oil: 0.26 lb/MMBtu heat input rolling 24-hour and 0.20 lb/MMBtu heat input rolling 30-day • Fuel oil: 0.30 lb/MMBtu heat input rolling 24-hour • Mixture of natural gas and fuel oil: heat input weighted average of applicable (above) specifications rolling 24-hour according to §117.1005(d) • Or applicable NSPS NOx emission limit in Subparts D, Db, or Dc <p>Stationary gas turbines:</p> <ul style="list-style-type: none"> • Non-peaking units \geq 30 MW (annual MWh \geq 2500 hours X unit MW rating): <ul style="list-style-type: none"> <input type="checkbox"/> Natural gas: 42 ppmv (15% O₂, dry) block one-hour <input type="checkbox"/> Fuel oil: 65 ppmv (15% O₂, dry) block one-hour • Peaking units (annual MWh < 2500 hours X unit MW rating): <ul style="list-style-type: none"> <input type="checkbox"/> Natural gas: 0.20 lb/MMBtu heat input block one-hour <input type="checkbox"/> Fuel oil: 0.30 lb/MMBtu heat input block one-hour | | |
| Utah | R307-424 Permits: Mercury Requirements for Electric Generating Units | Hg | 90% removal of Hg content of fuel annually or 0.65 lbs/MMBtu for all coal units > 25 MW | 2013 | |
| Washington | Washington State House Bill 3141 | CO ₂ | \$1.6/Tonne cost (2004\$) for all new fossil-fuel power plant | 2004 | |
| | Washington State House Bill 5769 | CO ₂ | 970 lbs/MWh rate limit for new coal plants | 2011 | |
| | Washington State SB5126 | CO ₂ | Establishes a cap-and-trade program for greenhouse gases to be implemented by the Department of Ecology. | 2028 | |

| State/Region | Bill | Emission Type | Emission Specifications | Implementation Status | Notes |
|--------------|--|-----------------|--|-----------------------|------------------------------------|
| | | | Updated statewide emissions reduction limits to 95% reduction below 1990 levels by 2050, with interim limit of 45% below 1990 levels by 2030 and 70% below 1990 levels by 2040. | | |
| Wisconsin | NR 428 Wisconsin Administration Code | NO _x | Annual rate limits for coal fired boilers > 1,000 MMBtu/hr: Wall fired, tangential fired, cyclone fired, and fluidized bed: 0.10 lbs/MMBtu (2013 onward) Arch fired: 0.18 lbs/MMBtu (2009 onward) | 2009 | |
| | | | Annual rate limits for coal fired boilers between 500 and 1,000 MMBtu/hr: Wall-fired with a heat release rate => 17,000 Btu per cubic feet per hour: 0.17 lbs/MMBtu (2013 onward); if heat input is lesser: Tangential fired: 0.15 lbs/MMBtu (2009 onward) Cyclone fired: 0.15 lbs/MMBtu (2013 onward) Fluidized bed: 0.10 lbs/MMBtu (2013 onward) Arch fired: 0.18 lbs/MMBtu (2009 onward) | | |
| | | | Annual rate limits for coal fired boilers between 250 and 500 MMBtu/hr: Same as for coal fired boilers between 500 and 1000 MMBtu/hr, in addition; Stoker Fired: 0.20 lbs/MMBtu | | |
| | | | Annual rate limits for coal fired boilers between 50 and 250 MMBtu/hr: Same as for coal boiled between 500 and 1000 MMBtu/hr, in addition; Stoker Fired: 0.25 lbs/MMBtu | | |
| | | | Annual rate limits for Combustion Turbines: Natural gas CTs > 50 MW: 0.11 lbs/MMBtu Distillate oil CTs > 50 MW: 0.28 lbs/MMBtu Biologically derived fuel CTs > 50 MW: 0.15 lbs/MMBtu Natural gas CTs between 25 and 49 MW: 0.19 lbs/MMBtu Distillate oil CTs between 25 and 49 MW: 0.41 lbs/MMBtu Biologically derived fuel CTs between 25 and 49 MW: 0.15 lbs/MMBtu | | |
| | | | Annual rate limits for Combined Cycle: Natural gas CCs > 25 MW: 0.04 lbs/MMBtu Distillate oil CCs > 25 MW: 0.18 lbs/MMBtu Biologically derived fuel CCs > 25 MWs: 0.15 lbs/MMBtu Natural gas CCs between 10 and 24 MW: 0.19 lbs/MMBtu | | |
| | | | | | |
| | Chapter NR 44.12/446.13 Control of Mercury Emissions | Hg | Large (150MW capacity or greater) or small (between 25 and 150 MW) coal fired EGU, 2015 onwards: 90% removal of Hg content of fuel or 0.0080 lbs/GWh reduction in coal fired EGUs > 150 MW | 2015 | |
| | Chapter NR 446.14 Multi-pollutant reduction alternative for coal-fired electrical generating units | Hg | All Coal>25MW; 70% reduction in fuel, or 0.0190 lbs per GW-hr from CY 2015 – CY 2017 80% reduction in fuel, or 0.0130 lbs per GW-hr from CY2018 – CY 2020 90% reduction in fuel, or 0.0080 lbs per GW-hr from January 1, 2021 onwards | 2015 | Alternative already modeled in IPM |