


JOSH STEIN
Governor

D. REID WILSON
Secretary

MICHAEL ABRACZINSKAS
Director



NORTH CAROLINA
Environmental Quality

January 6, 2025

David Greiner
Area Manager – VA South
Transcanada/Columbia Pipeline Group
2700 Veeco Street
Chesapeake, VA 23323

SUBJECT: Air Quality Permit No. 09186T05
Facility ID: 6600074
Pleasant Hill Compressor Station
Pleasant Hill
Northampton County
Fee Class: Title V
PSD Class: Minor

Dear Mr. Greiner:

In accordance with your completed Air Quality Permit Application for a renewal of your Title V permit, we are forwarding, herewith, Air Quality Permit No. 09186T05 authorizing the construction and operation of the emission source(s) and associated air pollution control device(s) specified herein. Additionally, any emissions activities determined from your Air Quality Permit Application as being insignificant per 15A North Carolina Administrative Code 02Q .0503(8) have been identified as such in the permit. Please note, the requirements for the annual compliance certification are contained in General Condition P in Section 4. The current owner is responsible for submitting a compliance certification for the entire year regardless of who owned the facility during the year.

As the designated responsible official, it is your responsibility to review, understand, and abide by all of the terms and conditions of the attached permit. It is also your responsibility to ensure that any person who operates any emission source and associated air pollution control device subject to any term or condition of the attached permit reviews, understands, and abides by the condition(s) of the attached permit that are applicable to that particular emission source.

If any parts, requirements, or limitations contained in this Air Quality Permit are unacceptable to you, you have the right to file a petition for contested case hearing in the North Carolina Office of Administrative Hearings. Information regarding the right, procedure, and time limit for permittees and other persons aggrieved to file such a petition is contained in the attached "Notice Regarding the Right to Contest a Division of Air Quality Permit Decision."

The construction of new air pollution emission source(s) and associated air pollution control device(s), or modifications to existing emission source(s) and air pollution control device(s) described in this permit must be covered under an Air Quality Permit issued by the Division of Air Quality prior to construction unless the Permittee has fulfilled the requirements of NCGS 143-215.108A(b) and received written approval from the Director of the Division of Air Quality to commence construction. Failure to receive an Air Quality Permit or written approval prior to commencing construction is a violation of NCGS



North Carolina Department of Environmental Quality | Division of Air Quality
217 West Jones Street | 1641 Mail Service Center | Raleigh, North Carolina 27699-1641
919.707.8400

Mr. David Greiner
January 6, 2025
Page 2

143-215.108A and may subject the Permittee to civil or criminal penalties as described in NCGS 143-215.114A and 143-215.114B.

Northampton County has triggered increment tracking under PSD for PM₁₀, SO₂, and NO_x. However, this permit renewal does not consume or expand increments for any pollutants.

This Air Quality Permit shall be effective from January 6, 2025 until December 31, 2029, is nontransferable to future owners and operators, and shall be subject to the conditions and limitations as specified therein.

Should you have any questions concerning this matter, please contact Luke Mayer by phone at (919) 707-8042 or by email at luke.mayer@deq.nc.gov.

Sincerely yours,



Mark J. Cuilla, EIT, CPM, Chief, Permitting Section
Division of Air Quality, NCDEQ

Enclosure

c: Brad Akers, EPA Region 4 (Permit and Review)
Laserfiche (6600074)

**NOTICE REGARDING THE RIGHT TO CONTEST A DIVISION OF AIR QUALITY PERMIT
DECISION**

Right of the Permit Applicant or Permittee to File a Contested Case: Pursuant to NCGS 143-215.108(e), a permit applicant or permittee who is dissatisfied with the Division of Air Quality's decision on a permit application may commence a contested case by filing a petition under NCGS 150B-23 in the Office of Administrative Hearings within 30 days after the Division notifies the applicant or permittee of its decision. If the applicant or permittee does not file a petition within the required time, the Division's decision on the application is final and is not subject to review. The filing of a petition will stay the Division's decision until resolution of the contested case.

Right of Other Persons Aggrieved to File a Contested Case: Pursuant to NCGS 143-215.108(e1), a person other than an applicant or permittee who is a person aggrieved by the Division's decision on a permit application may commence a contested case by filing a petition under NCGS 150B-23 within 30 days after the Division provides notice of its decision on a permit application, as provided in NCGS 150B-23(f), or by posting the decision on a publicly available Web site. The filing of a petition under this subsection does not stay the Division's decision except as ordered by the administrative law judge under NCGS 150B-33(b).

General Filing Instructions: A petition for contested case hearing must be in the form of a written petition, conforming to NCGS 150B-23, and filed with the Office of Administrative Hearings, 1711 New Hope Church Road, Raleigh NC, 27609, along with a fee in an amount provided in NCGS 150B-23.2. A petition for contested case hearing form may be obtained upon request from the Office of Administrative Hearings or on its website at <https://www.oah.nc.gov/hearings-division/filing/hearing-forms>. Additional specific instructions for filing a petition are set forth at 26 NCAC Chapter 03.

Service Instructions: A party filing a contested case is required to serve a copy of the petition, by any means authorized under 26 NCAC 03 .0102, on the process agent for the Department of Environmental Quality:

William F. Lane, General Counsel
North Carolina Department of Environmental Quality
1601 Mail Service Center
Raleigh, North Carolina 27699-1601

If the party filing the petition is a person aggrieved other than the permittee or permit applicant, the party **must also** serve the permittee in accordance with NCGS 150B-23(a).

* * *

Additional information is available at <https://www.oah.nc.gov/hearings-division/hearing-process/filing-contested-case>. Please contact the OAH at 984-236-1850 or oah.postmaster@oah.nc.gov with all questions regarding the filing fee and/or the details of the filing process.

Summary of Changes to Permit

The following changes were made to Air Permit No. 09186T05:*

Page No.	Section	Description of Changes
Cover letter and throughout permit	--	<ul style="list-style-type: none"> • Updated all dates and permit revision numbers • Reformatted permit in accordance with current TV permitting shell
5-11	2.1 A.3, A.4, and A.5	<ul style="list-style-type: none"> • Updated permit language in accordance with current TV permitting shell and revised incorrect references
6-10	2.1 A.3, A.4	<ul style="list-style-type: none"> • Minor revisions to language for clarity • Revised permit conditions to reflect 08/30/2024 regulatory updates to 40 CFR 63 Subpart ZZZZ
9	2.1 A.4	<ul style="list-style-type: none"> • Revised incorrect internal references
9, 10	2.1 A.5	<ul style="list-style-type: none"> • Minor revisions for clarity about which permit issuance triggered PSD conditions • Addition of equations for emissions monitoring • Replaced language for initial performance testing with language for periodic performance testing as initial testing requirements have been met
12	2.2	<ul style="list-style-type: none"> • Added permit shield for nonapplicable regulations
13	3	<ul style="list-style-type: none"> • Added new insignificant source IA-MS, a renewable natural gas metering station, to the insignificant sources list.
14-21	4	<ul style="list-style-type: none"> • Updated General Conditions with most recent version (Version 8 dated 07/10/2024)

* This list is not intended to be a detailed record of every change made to the permit but a summary of those changes.



State of North Carolina
Department of Environmental Quality
Division of Air Quality

AIR QUALITY PERMIT

Permit No.	Replaces Permit No.(s)	Effective Date	Expiration Date
09186T05	09186T04	January 6, 2025	December 31, 2029

NOTE: Per General Condition K, a permit application for the renewal of this Title V permit shall be submitted no later than June 30, 2029.

Until such time as this permit expires or is modified or revoked, the below named Permittee is permitted to construct and operate the emission source(s) and associated air pollution control device(s) specified herein, in accordance with the terms, conditions, and limitations within this permit. This permit is issued under the provisions of Article 21B of Chapter 143, General Statutes of North Carolina as amended, and Title 15A North Carolina Administrative Codes (15A NCAC), Subchapters 02D and 02Q, and other applicable Laws.

Pursuant to Title 15A NCAC, Subchapter 02Q, the Permittee shall not construct, operate, or modify any emission source(s) or air pollution control device(s) without having first submitted a complete Air Quality Permit Application to the permitting authority and received an Air Quality Permit, except as provided in this permit.

Permittee: **Pleasant Hill Compressor Station**
Facility ID: 6600074
Primary SIC Code: 4922
NAICS Code: 486210

Facility Site Location: 2784 NC 48 Hwy
City, County, State, Zip: Pleasant Hill, NC 27866
Mailing Address: 2700 Vepco Street
City, State, Zip: Chesapeake, VA 23323

Application Number(s): 6600074.24A
Complete Application Date(s): July 8, 2024

Division of Air Quality,
Regional Office Address: **Raleigh Regional Office**
3800 Barrett Drive
Raleigh, NC 27609

Permit issued this the 6th day of January, 2025.

Mark J. Cuilla, EIT, CPM, Chief, Air Permitting Section
By Authority of the Environmental Management Commission

Table of Contents

LIST OF ACRONYMS

- SECTION 1: PERMITTED EMISSION SOURCE(S) AND ASSOCIATED AIR POLLUTION CONTROL DEVICE(S) AND APPURTENANCES
- SECTION 2: SPECIFIC LIMITATIONS AND CONDITIONS
- 2.1 Emission Source(s) Specific Limitations and Conditions (Including specific requirements, testing, monitoring, recordkeeping, and reporting requirements)
 - 2.2 Permit Shield for Non-applicable Requirements
- SECTION 3: INSIGNIFICANT ACTIVITIES PER 15A NCAC 02Q .0503(8)
- SECTION 4: GENERAL PERMIT CONDITIONS

List of Acronyms

AOS	Alternative Operating Scenario
BACT	Best Available Control Technology
BAE	Baseline Actual Emissions
Btu	British thermal unit
CAA	Clean Air Act
CAM	Compliance Assurance Monitoring
CEMS	Continuous Emission Monitoring System
CEDRI	Compliance and Emissions Data Reporting Interface
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COMS	Continuous Opacity Monitoring System
CSAPR	Cross-State Air Pollution Rule
DAQ	Division of Air Quality
DEQ	Department of Environmental Quality
EMC	Environmental Management Commission
EPA	Environmental Protection Agency
FR	Federal Register
GACT	Generally Available Control Technology
GHGs	Greenhouse Gases
HAP	Hazardous Air Pollutant
LAER	Lowest Achievable Emission Rate
MACT	Maximum Achievable Control Technology
NAA	Non-Attainment Area
NAAQS	National Ambient Air Quality Standards
NAICS	North American Industry Classification System
NCAC	North Carolina Administrative Code
NCGS	North Carolina General Statutes
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO_x	Nitrogen Oxides
NSPS	New Source Performance Standard
NSR	New Source Review
OAH	Office of Administrative Hearings
PAE	Projected Actual Emissions
PAL	Plantwide Applicability Limitation
PM	Particulate Matter
PM_{2.5}	Particulate Matter with Nominal Aerodynamic Diameter of 2.5 Micrometers or Less
PM₁₀	Particulate Matter with Nominal Aerodynamic Diameter of 10 Micrometers or Less
POS	Primary Operating Scenario
PSD	Prevention of Significant Deterioration
PTE	Potential to Emit
RACT	Reasonably Available Control Technology
SIC	Standard Industrial Classification
SIP	State Implementation Plan
SO₂	Sulfur Dioxide
TAP	Toxic Air Pollutant
tpy	Tons Per Year
VOC	Volatile Organic Compound

SECTION 1 - PERMITTED EMISSION SOURCE(S) AND ASSOCIATED AIR POLLUTION CONTROL DEVICE(S) AND APPURTENANCES

The following table contains a summary of all permitted emission sources and associated air pollution control devices and appurtenances:

Emission Source ID No.	Emission Source Description	Control Device ID No.	Control Device Description
ES-15301 (GACT ZZZZ)	One natural gas-fired, White-Superior 6G-825 four-stroke rich burn (4SRB) reciprocating engine/compressor (467 horsepower site rated or 3.625 million Btu per hour firing rate)	NA	NA
ES-15302 (GACT ZZZZ)	One natural gas-fired, White-Superior 6G-825 four-stroke rich burn (4SRB) reciprocating engine/compressor (467 horsepower site rated or 3.625 million Btu per hour firing rate)	NA	NA
ES-15303 (GACT ZZZZ)	One natural gas-fired, White-Superior 6G-825 four-stroke rich burn (4SRB) reciprocating engine/compressor (467 horsepower site rated or 3.625 million Btu per hour firing rate)	NA	NA
ES-153G1 (GACT ZZZZ)	One natural gas-fired, Waukesha VSG11GSI, four-stroke rich burn (4SRB) emergency generator (250 horsepower site rated, 150 kilowatt capacity)	NA	NA

SECTION 2 - SPECIFIC LIMITATIONS AND CONDITIONS

2.1 Emission Source(s) and Control Device(s) Specific Limitations and Conditions

The emission source(s) and associated air pollution control device(s) and appurtenances listed below are subject to the following specific terms, conditions, and limitations, including the testing, monitoring, recordkeeping, and reporting requirements as specified herein:

A. Four-Stroke Rich Burn (4SRB) Engines:

- **Three natural gas-fired reciprocating engines/compressors (ID Nos. ES-15301, ES-15302, and ES-15303)**
- **One natural gas-fired reciprocating emergency generator (ID No. ES-153G1)**

The following table provides a summary of limits and standards for the emission source(s) described above:

Pollutant	Limits/Standards	Applicable Regulation
Sulfur dioxide	2.3 pounds per million Btu heat input	15A NCAC 02D .0516
Visible emissions	20 percent opacity	15A NCAC 02D .0521
Hazardous air pollutants	National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines	15A NCAC 02D .1111 40 CFR 63 Subpart ZZZZ
Nitrogen oxides	See Section 2.1 A.5	15A NCAC 02Q .0317 (PSD Avoidance)
Carbon monoxide	See Section 2.1 A.5	15A NCAC 02Q .0317 (PSD Avoidance)

1. 15A NCAC 02D .0516: SULFUR DIOXIDE EMISSIONS FROM COMBUSTION SOURCES

- a. Emissions of sulfur dioxide from these sources (**ID Nos. ES-15301, ES-15302, ES-15303, and ES-153G1**) shall not exceed 2.3 pounds per million Btu heat input. Sulfur dioxide formed by the combustion of sulfur in fuels, wastes, ores, and other substances shall be included when determining compliance with this standard.

Testing [15A NCAC 02Q .0508(f)]

- b. If emissions testing is required, the testing shall be performed in accordance with General Condition JJ. If the results of this test are above the limit given in Section 2.1 A.1.a above, the Permittee shall be deemed in noncompliance with 15A NCAC 02D .0516.

Monitoring/Recordkeeping/Reporting [15A NCAC 02Q .0508(f)]

- c. No monitoring/recordkeeping/reporting is required for sulfur dioxide emissions from the firing of natural gas in these sources.

2. 15A NCAC 02D .0521: CONTROL OF VISIBLE EMISSIONS

- a. Visible emissions from these sources (**ID Nos. ES-15301, ES-15302, ES-15303, and ES-153G1**) shall not be more than 20 percent opacity when averaged over a six-minute period. However, six-minute averaging periods may exceed 20 percent not more than once in any hour and not more than four times in any 24-hour period. In no event shall the six-minute average exceed 87 percent opacity.

Testing [15A NCAC 02Q .0508(f)]

- b. If emissions testing is required, the testing shall be performed in accordance with General Condition JJ. If the results of this test are above the limit given in Section 2.1 A.2.a above, the Permittee shall be deemed in noncompliance with 15A NCAC 02D .0521.
- c. No monitoring/recordkeeping/reporting is required for visible emissions from the firing of natural gas in these sources.

3. 15A NCAC 02D .1111: MAXIMUM ACHIEVABLE CONTROL TECHNOLOGY

Applicability [40 CFR 63.6585, 63.6590(a)(1)(iii)]

- a. For these emission sources (**ID Nos. ES-15301, ES-15302, and ES-15303**) (existing 4-stroke rich burn (4SRB) nonemergency engines located at an area source) the Permittee shall comply with all applicable provisions, including the monitoring, recordkeeping, and reporting contained in Environmental Management Commission Standard 15A NCAC 02D .1111 “Maximum Achievable Control Technology” (MACT) as promulgated in 40 CFR 63, “Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines” and Subpart A “General Provisions.”

Definitions and Nomenclature

- b. For the purposes of this permit condition, the definitions and nomenclature contained in 40 CFR 63.6675 shall apply.

Applicability Date [40 CFR 63.6595(a)(1)]

- c. The Permittee shall comply with the applicable emission limitations, operating limitations, and other requirements no later than October 19, 2013.

Notifications [40 CFR 63.6645(a)(5)]

- d. The Permittee has no notification requirements.

General Provisions [40 CFR 63.6665]

- e. The Permittee shall comply with the General Provisions as applicable pursuant to Table 8 of 40 CFR 63 Subpart ZZZZ.

Operating and Maintenance Requirements [15A NCAC 02Q .0508(b)]

- f. During periods of startup of the internal combustion (IC) engine, the Permittee shall minimize the engine’s time spent at idle during startup and minimize the engine’s startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. [40 CFR 63.6625(h)]
- g. Except during periods of startup of the IC engine, the Permittee shall:
 - i. Change oil and filter every 1,440 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;
 - ii. Inspect spark plugs every 1,440 hours of operation or within 1 year + 30 days of the previous change, whichever comes first and replace as necessary; and
 - iii. Inspect all hoses and belts every 1,440 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary.[40 CFR 63.6603(a), Table 2d]
- h. The Permittee shall have the option to utilize the oil analysis program as described in 40 CFR 63.6625(j) in order to extend the specified oil and filter change requirement in Table 2d to this Subpart (Section 2.1 A.3.g above). The oil analysis shall be performed at the same frequency specified for changing the oil and filter in Table 2d to this Subpart (Section 2.1 A.3.g above). [40 CFR 63.6603(a), Table 2d, 63.6625(j)]
- i. The Permittee shall be in compliance with the emission limitations, operating limitations, and other requirements that apply at all times. [40 CFR 63.6605(a)]
- j. The Permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the Permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source [40 CFR 63.6605(b)]
- k. The Permittee shall operate and maintain the stationary reciprocating internal combustion engine (RICE) and after-treatment control device (if any) according to the manufacturer’s emission-related written instructions or develop a maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63.6625(e) and 63.6640(a), Table 6]

Recordkeeping [15A NCAC 02Q .0508(f)]

- l. The Permittee shall keep the following:
 - i. A copy of each notification and report that they submitted to comply with this Subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that they submitted, according to the requirement in 40 CFR 63.10(b)(2)(xiv). [40 CFR 63.6655(a)(1)]
 - ii. Records of the occurrence and duration (in hours) of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. [40 CFR 63.6655(a)(2)]
 - iii. Records of all required maintenance performed on the air pollution control and monitoring equipment. [40 CFR 63.6655(a)(4)]
 - iv. Records of actions taken during periods of malfunction to minimize emissions in accordance with Section 2.1 A.3.j above, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63.6655(a)(5)]
 - v. Records of the maintenance conducted on the RICE pursuant to Section 2.1 A.3.k. [40 CFR 63.6655(d) and (e)]
- m. The Permittee shall keep each record in a form suitable and readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). [40 CFR 63.6660(a), (b), (c)]

Reporting [15A NCAC 02Q .0508(f)]

- n. The Permittee shall submit a summary report of monitoring and recordkeeping activities postmarked on or before January 30 of each calendar year for the preceding six-month period between July and December, and July 30 of each calendar year for the preceding six-month period between January and June. The report shall also include the information at 40 CFR 63.6650(c). All instances of noncompliance must be clearly identified.
- o. Beginning on February 26, 2025, the semiannual compliance report required in Table 7 of this Subpart shall be submitted according to 40 CFR 63.6650 (i) of this section. Only those elements required under this Subpart are required to be submitted according to 40 CFR 63.6650 (i) of this section. [40 CFR 63.6650(f)]
- p. Beginning on February 26, 2025 for the annual report specified in 40 CFR 63.6650(h) and February 26, 2025 or one year after the report becomes available in CEDRI, whichever is later for all other semiannual or annual reports, the Permittee shall submit all semiannual and annual subsequent compliance reports using the appropriate electronic report template on the CEDRI website (<https://www.epa.gov/electronic-reporting-air-emissions/cedri>) for this Subpart and following the procedure specified in 40 CFR 63.9(k), except any CBI must be submitted according to the procedures in 40 CFR 63.6645(h). The date report templates become available will be listed on the CEDRI website. Unless the Administrator or delegated state agency or other authority has approved a different schedule for submission of reports, the report shall be submitted by the deadline specified in this Subpart, regardless of the method in which the report is submitted. [40 CFR 63.6650(i)]
- q. The Permittee shall be deemed in noncompliance with 15A NCAC 02D .1111 if the requirements in Section 2.1 A.3.e through p above are not met. [40 CFR 63.6640(b) and (e), 63.6650(c), (f), and (i), and Table 7]

4. 15A NCAC 02D .1111: MAXIMUM ACHIEVABLE CONTROL TECHNOLOGY**Applicability** [40 CFR 63.6585, 63.6590(a)(1)(iii)]

- a. For this emission source (**ID No. ES-153G1**) (existing 4SRB emergency engine located at an area source), the Permittee shall comply with all applicable provisions, including the monitoring, recordkeeping, and reporting contained in Environmental Management Commission Standard 15A NCAC 02D .1111 “Maximum Achievable Control Technology (MACT) as promulgated in 40 CFR 63, “Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines” and Subpart A “General Provisions.”

Definitions and Nomenclature

- b. For the purposes of this permit condition, the definitions and nomenclature contained in 40 CFR 63.6675 shall apply.

Applicability Date [40 CFR 63.6595(a)(1)]

- c. The Permittee shall comply with the applicable emission limitations, and other requirements no later than October 19, 2013.

Notifications [40 CFR 63.6645(a)(5)]

- d. The Permittee has no notification requirements.

General Provisions [40 CFR 63.6665]

- e. The Permittee shall comply with the General Provisions as applicable pursuant to Table 8 of 40 CFR 63 Subpart ZZZZ.

Operating and Maintenance Requirements [15A NCAC 02Q .0508(b)]

- f. During periods of startup of the IC engine, the Permittee shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. [40 CFR 63.6625(h)]
- g. Except during periods of startup of the IC engine, the Permittee shall:
 - i. Change oil and filters every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;
 - ii. Inspect spark plugs every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first; and
 - iii. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary. [40 CFR 63.6603(a), Table 2d]
- h. The Permittee shall have the option to utilize the oil analysis program as described in 40 CFR 63.6625(j) in order to extend the specified oil and filter change requirement in Table 2d to this Subpart (Section 2.1 A.4.g above). The oil analysis must be performed at the same frequency specified for changing the oil and filter in Table 2d to this Subpart (Section 2.1 A.4.g above). [40 CFR 63.6603(a), Table 2d, 63.6625(i)]
- i. If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Section 2.1 A.4.g above, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. [40 CFR 63.6603(a), Table 2d]
- j. The Permittee shall be in noncompliance with the emission limitations, operating limitations and other requirements that apply at all times. [40 CFR 63.6605(a)]
- k. The Permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the Permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.6605(b)]
- l. The Permittee shall operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop a maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63.6625(e) and 63.6640(a), Table 6]
- m. In order for the engine to be considered an emergency stationary RICE under this condition, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (i) through (iii) below, is prohibited.
 - i. There is no time limit on the use of emergency stationary RICE in emergency situations.
 - ii. The Permittee may operate the emergency stationary RICE for any combination of the purposes specified in paragraph (A) below for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (3) below counts as part of the 100 hours per calendar year allowed by this paragraph (2).
 - (A) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are commenced by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
 - iii. Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (m)(ii) above. Except as provided in Section 2.1 A.4.m.(iii)(A) below, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
 - (A) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

- (1) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
- (2) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
- (3) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
- (4) The power is provided only to the facility itself or to support the local transmission and distribution system.
- (5) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[40 CFR 63.6640(f)]

- n. The Permittee shall be deemed in noncompliance with 15A NCAC 02D .1111 if the conditions in Section 2.1 A.4.e through m are not met.

Monitoring [15A NCAC 02Q .0508(f)]

- o. The Permittee shall install a non-resettable hour meter on the IC engine if one is not already installed. [40 CFR 63.6625(f)]

Recordkeeping [15A NCAC 02Q .0508(f)]

- p. The Permittee shall keep the following:
- i. A copy of each notification and report that they submitted to comply with this Subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that they submitted, according to the requirement in 40 CFR 63.10(b)(2)(xiv). [40 CFR 63.6655(a)(1)]
 - ii. Records of the occurrence and duration (in hours) of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. [40 CFR 63.6655(a)(2)]
 - iii. Records of all required maintenance performed on the air pollution control and monitoring equipment. [40 CFR 63.6655(a)(4)]
 - iv. Records of actions taken during periods of malfunction to minimize emissions in accordance with Section 2.1 A.4.k., including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63.6655(a)(5)]
 - v. Records of the maintenance conducted on the RICE pursuant to Section 2.1 A.4.l. [40 CFR 63.6655(d) and (e)]
 - vi. Records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The Permittee shall document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation.
(A) If the engine is used for the purposes specified in Section 2.1 A.4.m.(iii)(A)(1) through (5) above, the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes. [40 CFR 63.6655(f)]
- q. Each record must be kept in a form suitable and readily available in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). [40 CFR 63.6660(a), (b), (c)]
- r. The Permittee shall be deemed in noncompliance with 15A NCAC 02D .1111 if the conditions in Section 2.1 A.4.p through r are not met.

Reporting [15A NCAC 02Q .0508(f)]

- s. The Permittee shall submit a summary report of monitoring and recordkeeping activities postmarked on or before January 30 of each calendar year for the preceding six-month period between July and December and July 30 of each calendar year for the preceding six-month period between January and June. All instances of noncompliance must be clearly identified.
- i. The summary report shall also include any reporting required under Section 2.1 A.4.i, as necessary. [40 CFR 63.6650(f)]
- t. Beginning on February 26, 2025, the semiannual compliance report required in Table 7 of this Subpart must be submitted according to 40 CFR 63.6650 (i) of this section. Only those elements required under this Subpart are required to be submitted according to 40 CFR 63.6650 (i) of this section. [40 CFR 63.6640(b), (e), and 63.6650(f)]
- u. Beginning on February 26, 2025 for the annual report specified in 40 CFR 63.6650(h) and February 26, 2025 or one year after the report becomes available in CEDRI, whichever is later for all other semiannual or annual reports, the Permittee shall submit all semiannual and annual subsequent compliance reports using the appropriate electronic report template on

the CEDRI website (<https://www.epa.gov/electronic-reporting-air-emissions/cedri>) for this Subpart and following the procedure specified in 40 CFR 63.9(k), except any CBI must be submitted according to the procedures in 40 CFR 63.6645(h). The date report templates become available will be listed on the CEDRI website. Unless the Administrator or delegated state agency or other authority has approved a different schedule for submission of reports, the report shall be submitted by the deadline specified in this Subpart, regardless of the method in which the report is submitted. [40 CFR 63.6650(i)]

- v. If the Permittee owns or operates an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in Section 2.1 A.4.m.(iii)(A)(1) through (5) above, the Permittee shall submit an annual report according to the requirements at 40 CFR 63.6650(h). This report must be submitted to the Regional Supervisor and the EPA. [40 CFR 63.6650(h)]
- w. The Permittee shall be deemed in noncompliance with the reporting requirements of 15A NCAC 02D .1111 if the requirements in Sections 2.1 A.4.s through v are not met.

5. 15A NCAC 02Q .0317: AVOIDANCE CONDITIONS

For 15A NCAC 02D .0530: PREVENTION OF SIGNIFICANT DETERIORATION

- a. In order to avoid applicability of this regulation, these sources (**ID Nos. ES-15301, ES-15302, ES-15303, and ES-153G1**) shall discharge into the atmosphere less than:
 - i. 250 tons of nitrogen oxides (NO_x) per consecutive 12-month period.
 - ii. 250 tons of carbon monoxide (CO) per consecutive 12-month period.

Testing [15A NCAC 02Q .0508(f)]

- b. **Performance Tests** – Under the provisions of North Carolina General Statute 143-215.108, the Permittee shall demonstrate compliance with the PSD avoidance in Section 2.1 A.5.a above by conducting periodic performance tests on the three natural gas-fired compressor engines (**ID No. ES-15301, ES-15302, and ES-15303**) and the natural gas-fired emergency generator (**ID No. ES-153G1**) for NO_x and CO emissions. Periodic testing shall be conducted in accordance with the following:
 - i. Details of the emissions testing and reporting requirements can be found in General Condition JJ. If the results of this test are above the limit given in Section 2.1 A.5.a above, the Permittee shall be deemed in noncompliance with 15A NCAC 02D .0530.
 - ii. The Permittee shall conduct periodic performance tests at a minimum of every five years from the previous test.
 - (A) If the results of emission testing show emission factors lower than those currently listed in Section 2.1 A.5.c below (i.e., the results are less stringent than the Title V permit), the Permittee may request to revise the pertinent value(s) in the permit by submitting an application for permit modification pursuant to 15A NCAC 02Q .0515 within 60 days of conducting a test.
 - (B) If the results of emission testing show emission factors higher than those currently listed in Section 2.1 A.5.c (i.e., the results are more stringent than the Title V permit), the Permittee shall request to revise the pertinent value(s) in the permit pursuant to 15A NCAC 02Q .0514. The request shall be submitted with results of the testing required by this Section 2.1 A.5.b.
 - iii. The Permittee shall comply with applicable emission standards at all times, including during periods of testing.

Monitoring/Recordkeeping [15A NCAC 02Q .0508(f)]

- c. Calculations of NO_x and CO emissions per month shall be made at the end of each month.
 - i. NO_x emissions shall be determined by multiplying the total amount of natural gas fired in these sources (**ID Nos. ES-15301, ES-15302, ES-15303, and ES-153G1**) during the month by the emissions factor for NO_x emissions determined in Section 2.1 A.5.b above. The Permittee shall calculate the monthly emissions of nitrogen oxides from the compressors and emergency generators according to the following equations:

$$\text{NO}_x \left(\frac{\text{tons}}{\text{month}} \right) = 0.00514 \frac{\text{lbNO}_x}{\text{bhp-hr}} \times R_1 \frac{\text{bhp-hr}}{\text{month}} \quad (\text{Engine ES-15301})$$

$$\text{NO}_x \left(\frac{\text{tons}}{\text{month}} \right) = 0.00485 \frac{\text{lbNO}_x}{\text{bhp-hr}} \times R_2 \frac{\text{bhp-hr}}{\text{month}} \quad (\text{Engine ES-15302})$$

$$\text{NO}_x \left(\frac{\text{tons}}{\text{month}} \right) = 0.00529 \frac{\text{lbNO}_x}{\text{hp-hr}} \times R_3 \frac{\text{bhp-hr}}{\text{month}} \quad (\text{Engine ES-15303})$$

$$\text{NO}_x \left(\frac{\text{tons}}{\text{month}} \right) = 0.01014 \frac{\text{lbNO}_x}{\text{bhp-hr}} \times R_G \frac{\text{bhp-hr}}{\text{month}} \text{ (Engine ES-153G1)}$$

Where:

- R₁ = Power output for compressor 1, ID No. ES-15301, in bhp-hr per month, if it burned fuel in a given month.
- R₂ = Power output for compressor 1, ID No. ES-15302, in bhp-hr per month, if it burned fuel in a given month.
- R₃ = Power output for compressor 3, ID No. ES-15303, in bhp-hr per month, if it burned fuel in a given month.
- R_G = Power output for emergency generator, ID No. ES-153G1, in bhp-hr per month, if it burned fuel in a given month.

- ii. CO emissions shall be determined by multiplying the total amount of natural gas fired in these sources (**ID Nos. ES-15301, ES-15302, ES-15303, and ES-153G1**) during the month by the emissions factor for CO emissions determined in Section 2.1 A.5.b above. The Permittee shall calculate the monthly emissions of carbon monoxide from the compressors and emergency generators according to the following equations:

$$\text{CO} \left(\frac{\text{tons}}{\text{month}} \right) = 0.00985 \frac{\text{lbCO}}{\text{bhp-hr}} \times R_1 \frac{\text{bhp-hr}}{\text{month}} \text{ (Engine ES-15301)}$$

$$\text{CO} \left(\frac{\text{tons}}{\text{month}} \right) = 0.00038 \frac{\text{lbCO}}{\text{bhp-hr}} \times R_2 \frac{\text{bhp-hr}}{\text{month}} \text{ (Engine ES-15302)}$$

$$\text{CO} \left(\frac{\text{tons}}{\text{month}} \right) = 0.0097 \frac{\text{lbCO}}{\text{bhp-hr}} \times R_3 \frac{\text{bhp-hr}}{\text{month}} \text{ (Engine ES-15303)}$$

$$\text{CO} \left(\frac{\text{tons}}{\text{month}} \right) = 0.0032 \frac{\text{lbCO}}{\text{bhp-hr}} \times R_G \frac{\text{bhp-hr}}{\text{month}} \text{ (Engine ES-153G1)}$$

Where:

- R₁ = Power output for compressor 1, ID No. ES-15301, in bhp-hr per month, if it burned fuel in a given month.
- R₂ = Power output for compressor 1, ID No. ES-15302, in bhp-hr per month, if it burned fuel in a given month.
- R₃ = Power output for compressor 3, ID No. ES-15303, in bhp-hr per month, if it burned fuel in a given month.
- R_G = Power output for emergency generator, ID No. ES-153G1, in bhp-hr per month, if it burned fuel in a given month.

The Permittee shall be deemed in noncompliance with 15A NCAC 02D .0530 if the amounts of natural gas fired in these sources, the NO_x emissions, or the CO emissions are not monitored and recorded.

- d. Calculations and the total amount of NO_x and CO emissions shall be recorded monthly in a logbook (written or electronic format). The Permittee shall be deemed in noncompliance with 15A NCAC 02D .0530 if these records are not kept or the NO_x and/or CO emissions exceed the limit in Section 2.1 A.5.a above.

Reporting [15A NCAC 02Q .0508(f)]

- e. The Permittee shall submit a summary report of monitoring and recordkeeping activities given in Section 2.1 A.5.d and e above postmarked on or before January 30 of each calendar year for the preceding six-month period between July and December and July 30 of each calendar year for the preceding six-month period between January and June. The report shall contain the monthly NO_x and CO emissions for the previous 17 months. The emissions must be calculated for each of the 12-month periods over the previous 17 months.

2.2 Permit Shield for Nonapplicable Requirements

The Permittee is shielded from the following nonapplicable requirements [15A NCAC 02Q .0512(a)(1)(B)].

- A. 15A NCAC 02D .0524 (40 CFR 60 Subpart Dc) is not applicable to the natural gas-fired hot water boiler (**ID No. IES-BLR1**) because the boiler size (maximum design heat input capacity) is less than the applicability threshold.
- B. 15A NCAC 02D .0524 (40 CFR 60 Subpart K) is not applicable to any petroleum liquid storage tanks (**ID Nos. IA-A01, IA-A02, IA-A03, and IA-A04**) at the facility because their sizes (storage capacities) are less than the applicability threshold.
- C. 15A NCAC 02D .0524 (40 CFR 60 Subpart Ka) is not applicable to any petroleum liquid storage tanks (**ID Nos. IA-A01, IA-A02, IA-A03, and IA-A04**) at the facility because their sizes (storage capacities) are less than the applicability threshold.
- D. 15A NCAC 02D .0524 (40 CFR 60 Subpart Kb) is not applicable to any petroleum liquid storage tanks (**ID Nos. IA-A01, IA-A02, IA-A03, and IA-A04**) at the facility because their sizes are less than the applicability threshold.
- E. 15A NCAC 02D .0524 (40 CFR 60 Subpart GG) is not applicable to the facility because it operates no stationary gas turbines.
- F. 15A NCAC 02D .0524 (40 CFR 60 Subpart LLL) is not applicable to the facility because it operates no sweetening units or sulfur recovery units.
- G. 15A NCAC 02D .0524 (40 CFR 60 Subpart JJJJ) is not applicable to any natural gas-fired engines (**ID Nos. ES-15301, ES-15302, ES-15303, and ES-153G1**) because they were constructed prior to that regulation's term of applicability.
- H. 15A NCAC 02D .0524 (40 CFR 60 Subpart KKKK) is not applicable to the facility because it operates no stationary combustion turbines.
- I. 15A NCAC 02D .0524 (40 CFR 60 Subpart OOOO) is not applicable to the wastewater storage tank (**ID No. IA-A06**) because the requirements defined for transmission sources are not applicable to this site.
- J. 15A NCAC 02D .0524 (40 CFR 60 Subpart OOOOa) is not applicable to the facility because nothing subject to this Subpart was constructed during the term of applicability.
- K. 15A NCAC 02D .0524 (40 CFR 60 Subpart OOOOb) is not applicable to the facility because nothing subject to this Subpart was constructed after the applicability threshold. This regulation does not apply to renewable natural gas (RNG) sources and, as such, is not applicable to the addition of the RNG meter station.
- L. 15A NCAC 02D .1111 (40 CFR 63 Subpart HH) is not applicable to the facility because it is in the "transmission facility" source category rather than the "production facility" source category.
- M. 15A NCAC 02D .1111 (40 CFR 63 Subpart HHH) is not applicable to the facility because it does not operate any glycol dehydration units.
- N. 15A NCAC 02D .1111 (40 CFR 63 Subpart YYYY) is not applicable to the facility because it is an area source of HAPs and this Subpart only applies to major sources.
- O. 15A NCAC 02D .1111 (40 CFR 63 Subpart DDDDD) is not applicable to the natural gas-fired boiler (**ID No. IA-BLR1**) because the boiler size (maximum design heat input capacity) is below the applicability threshold.
- P. 15A NCAC 02D .1111 (40 CFR 63 Subpart JJJJJ) is not applicable to the natural gas-fired boiler (**ID No. IA-BLR1**) because it fires only natural gas.

SECTION 3 - INSIGNIFICANT ACTIVITIES PER 15A NCAC 02Q .0503(8)

Emission Source ID No.	Emission Source Description ^{1,2}
IA-BLR1	One natural gas-fired Cleaver-Brooks Model WTW-703-1500 heating system/hot water boiler (1.5 million Btu per hour maximum heat input capacity)
IA-A01	One horizontal above-ground engine lube oil storage tank (1,126 gallon capacity)
IA-A02	One horizontal above-ground pipeline liquids storage tank (2,474 gallon capacity)
IA-A03	One horizontal above-ground ethylene glycol storage tank (1,126 gallon capacity)
IA-A04	One horizontal above-ground used engine lube oil storage tank (1,126 gallon capacity)
IA-A06	One horizontal above-ground wastewater storage tank (250 gallon capacity)
IA-PWD	Parts washer-degreaser (30 gallon capacity)
IA-MS	One renewable natural gas metering station

¹ Because an activity is insignificant does not mean that the activity is exempted from an applicable requirement (Federal or State) or that the Permittee is exempted from demonstrating compliance with any applicable requirement.

² When applicable, emissions from stationary source activities identified above shall be included in determining compliance with the permit requirements for toxic air pollutants under 15A NCAC 02D .1100 “Control of Toxic Air Pollutants” or 02Q .0711 “Emission Rates Requiring a Permit.”

SECTION 4 - GENERAL CONDITIONS (version 8.0, 07/10/2024)

This section describes terms and conditions applicable to this Title V facility.

- A. **General Provisions** [NCGS 143-215 and 15A NCAC 02Q .0508(i)(16)]
1. Terms not otherwise defined in this permit shall have the meaning assigned to such terms as defined in 15A NCAC 02D and 02Q.
 2. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to NCGS 143-215.114A and 143-215.114B, including assessment of civil and/or criminal penalties. Any unauthorized deviation from the conditions of this permit may constitute grounds for revocation and/or enforcement action by the DAQ.
 3. This permit is not a waiver of or approval of any other Department permits that may be required for other aspects of the facility which are not addressed in this permit.
 4. This permit does not relieve the Permittee from liability for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted facility, or from penalties therefore, nor does it allow the Permittee to cause pollution in contravention of state laws or rules, unless specifically authorized by an order from the North Carolina Environmental Management Commission.
 5. Except as identified as state-only requirements in this permit, all terms and conditions contained herein shall be enforceable by the DAQ, the EPA, and citizens of the United States as defined in the Federal Clean Air Act.
 6. Any stationary source of air pollution shall not be operated, maintained, or modified without the appropriate and valid permits issued by the DAQ, unless the source is exempted by rule. The DAQ may issue a permit only after it receives reasonable assurance that the installation will not cause air pollution in violation of any of the applicable requirements. A permitted installation may only be operated, maintained, constructed, expanded, or modified in a manner that is consistent with the terms of this permit.
- B. **Permit Availability** [15A NCAC 02Q .0507(k) and .0508(i)(9)(B)]
The Permittee shall have available at the facility a copy of this permit and shall retain for the duration of the permit term one complete copy of the application(s) and any information submitted in support of the application package. The permit and application shall be made available to an authorized representative of the Department of Environmental Quality upon request.
- C. **Severability Clause** [15A NCAC 02Q .0508(i)(2)]
In the event of an administrative challenge to a final and binding permit in which a condition is held to be invalid, the provisions in this permit are severable so that all requirements contained in the permit, except those held to be invalid, shall remain valid and must be complied with.
- D. **Submissions** [15A NCAC 02Q .0507(e) and 02Q .0508(i)(16)]
Except as otherwise specified herein, one copy of all documents, reports, test data, monitoring data, notifications, request for renewal, and any other information required by this permit shall be submitted to the appropriate Regional Office. Refer to the Regional Office address on the cover page of this permit. For continuous emissions monitoring systems (CEMS) reports, continuous opacity monitoring systems (COMS) reports, quality assurance (QA)/quality control (QC) reports, acid rain CEM certification reports, and NOx budget CEM certification reports, one copy shall be sent to the appropriate Regional Office and one copy shall be sent to:

Supervisor, Stationary Source Compliance
North Carolina Division of Air Quality
1641 Mail Service Center
Raleigh, NC 27699-1641
- All submittals shall include the facility name and Facility ID number (refer to the cover page of this permit).
- E. **Duty to Comply** [15A NCAC 02Q .0508(i)(3)]
The Permittee shall comply with all terms, conditions, requirements, limitations and restrictions set forth in this permit. Noncompliance with any permit condition except conditions identified as state-only requirements constitutes a violation of the Federal Clean Air Act. Noncompliance with any permit condition is grounds for enforcement action, for permit termination, revocation and reissuance, or modification, or for denial of a permit renewal application.

F. **Circumvention** - STATE ENFORCEABLE ONLY

The facility shall be properly operated and maintained at all times in a manner that will effect an overall reduction in air pollution. Unless otherwise specified by this permit, no emission source may be operated without the concurrent operation of its associated air pollution control device(s) and appurtenances.

G. **Title V Permit Modifications**

1. Administrative Permit Amendments [15A NCAC 02Q .0514]
The Permittee shall submit an application for an administrative permit amendment in accordance with 15A NCAC 02Q .0514.
2. Transfer in Ownership or Operation and Application Submittal Content [15A NCAC 02Q .0524 and 02Q .0505]
The Permittee shall submit an application for an ownership change in accordance with 15A NCAC 02Q.0524 and 02Q .0505.
3. Minor Permit Modifications [15A NCAC 02Q .0515]
The Permittee shall submit an application for a minor permit modification in accordance with 15A NCAC 02Q .0515.
4. Significant Permit Modifications [15A NCAC 02Q .0516]
The Permittee shall submit an application for a significant permit modification in accordance with 15A NCAC 02Q .0516.
5. Reopening for Cause [15A NCAC 02Q .0517]
The Permittee shall submit an application for reopening for cause in accordance with 15A NCAC 02Q .0517.

H. **Changes Not Requiring Permit Modifications**

1. Reporting Requirements [15A NCAC 02Q .0508(f)]
Any of the following that would result in new or increased emissions from the emission source(s) listed in Section 1 must be reported to the Regional Supervisor, DAQ:
 - a. changes in the information submitted in the application;
 - b. changes that modify equipment or processes; or
 - c. changes in the quantity or quality of materials processed.If appropriate, modifications to the permit may then be made by the DAQ to reflect any necessary changes in the permit conditions. In no case are any new or increased emissions allowed that will cause a violation of the emission limitations specified herein.
2. Section 502(b)(10) Changes [15A NCAC 02Q .0523(a)]
 - a. "Section 502(b)(10) changes" means changes that contravene an express permit term or condition. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements.
 - b. The Permittee may make Section 502(b)(10) changes without having the permit revised if:
 - i. the changes are not a modification under Title I of the Federal Clean Air Act;
 - ii. the changes do not cause the allowable emissions under the permit to be exceeded;
 - iii. the Permittee notifies the Director and EPA with written notification at least seven days before the change is made; and
 - iv. the Permittee shall attach the notice to the relevant permit.
 - c. The written notification shall include:
 - i. a description of the change;
 - ii. the date on which the change will occur;
 - iii. any change in emissions; and
 - iv. any permit term or condition that is no longer applicable as a result of the change.
 - d. Section 502(b)(10) changes shall be made in the permit the next time that the permit is revised or renewed, whichever comes first.
3. Off Permit Changes [15A NCAC 02Q .0523(b)]
The Permittee may make changes in the operation or emissions without revising the permit if:
 - a. the change affects only insignificant activities and the activities remain insignificant after the change; or
 - b. the change is not covered under any applicable requirement.
4. Emissions Trading [15A NCAC 02Q .0523(c)]
To the extent that emissions trading is allowed under 15A NCAC 02D, including subsequently adopted maximum achievable control technology standards, emissions trading shall be allowed without permit revision pursuant to 15A NCAC 02Q .0523(c).

I.A **Reporting Requirements for Excess Emissions** [15A NCAC 02D .0535(f) and 02Q .0508(f)(2)]

1. **“Excess Emissions”** - means an emission rate that exceeds any applicable emission limitation or standard allowed by any rule in Sections .0500, .0900, .1200, or .1400 of Subchapter 02D; or by a permit condition; or that exceeds an emission limit established in a permit issued under 15A NCAC 02Q .0700. *(Note: Definitions of excess emissions under 02D .1110 and 02D .1111 shall apply where defined by rule.)*
2. If a source is required to report excess emissions under NSPS (15A NCAC 02D .0524), NESHAPS (15A NCAC 02D .1110 or .1111), or the operating permit provides for periodic (e.g., quarterly) reporting of excess emissions, reporting shall be performed as prescribed therein.
3. If the source is not subject to NSPS (15A NCAC 02D .0524), NESHAPS (15A NCAC 02D .1110 or .1111), or these rules do NOT define "excess emissions," the Permittee shall report excess emissions in accordance with 15A NCAC 02D .0535 as follows:
 - a. Pursuant to 15A NCAC 02D .0535, if excess emissions last for more than four hours resulting from a malfunction, a breakdown of process or control equipment, or any other abnormal condition, the owner or operator shall:
 - i. notify the Regional Supervisor or Director of any such occurrence by 9:00 a.m. Eastern Time of the Division's next business day of becoming aware of the occurrence and provide:
 - name and location of the facility;
 - nature and cause of the malfunction or breakdown;
 - time when the malfunction or breakdown is first observed;
 - expected duration; and
 - estimated rate of emissions;
 - ii. notify the Regional Supervisor or Director immediately when corrective measures have been accomplished; and
 - iii. submit to the Regional Supervisor or Director within 15 days a written report as described in 15A NCAC 02D .0535(f)(3).

I.B Reporting Requirements for Permit Deviations [15A NCAC 02D .0535(f) and 02Q .0508(f)(2)]

1. **“Permit Deviations”** - for the purposes of this condition, any action or condition not in accordance with the terms and conditions of this permit including those attributable to upset conditions as well as excess emissions as defined above lasting less than four hours.
2. Pursuant to 15A NCAC 02Q .0508(f)(2), the Permittee shall report deviations from permit requirements (terms and conditions) quarterly by notifying the Regional Supervisor or Director of all other deviations from permit requirements not covered under 15A NCAC 02D .0535. A written report to the Regional Supervisor shall include the probable cause of such deviation and any corrective actions or preventative actions taken. The responsible official shall certify all deviations from permit requirements.

I.C Other Requirements under 15A NCAC 02D .0535

The Permittee shall comply with all other applicable requirements contained in 15A NCAC 02D .0535, including 15A NCAC 02D .0535(c) as follows:

1. Any excess emissions that do not occur during start-up and shut-down shall be considered a violation of the appropriate rule unless the owner or operator of the sources demonstrates to the Director that the excess emissions are a result of a malfunction. The Director shall consider, along with any other pertinent information, the criteria contained in 15A NCAC 02D .0535(c)(1) through (7).
2. 15A NCAC 02D .0535(g). Excess emissions during start-up and shut-down shall be considered a violation of the appropriate rule if the owner or operator cannot demonstrate that excess emissions are unavoidable.

J. RESERVED

K. Permit Renewal [15A NCAC 02Q .0508(e) and 02Q .0513(b)]

This 15A NCAC 02Q .0500 permit is issued for a fixed term not to exceed five years and shall expire at the end of its term. Permit expiration terminates the facility's right to operate unless a complete 15A NCAC 02Q .0500 renewal application is submitted at least six months before the date of permit expiration. If the Permittee or applicant has complied with 15A NCAC 02Q .0512(b)(1), this 15A NCAC 02Q .0500 permit shall not expire until the renewal permit has been issued or denied. Permit expiration under 15A NCAC 02Q .0400 terminates the facility's right to operate unless a complete 15A NCAC 02Q .0400 renewal application is submitted at least six months before the date of permit expiration for facilities subject to 15A NCAC 02Q .0400 requirements. In either of these events, all terms and conditions of these permits shall remain in effect until the renewal permits have been issued or denied.

L. Need to Halt or Reduce Activity Not a Defense [15A NCAC 02Q .0508(i)(4)]

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

M. **Duty to Provide Information (submittal of information)** [15A NCAC 02Q .0508(i)(9)]

1. The Permittee shall furnish to the DAQ, in a timely manner, any reasonable information that the Director may request in **writing** to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit.
2. The Permittee shall furnish the DAQ copies of records required to be kept by the permit when such copies are requested by the Director. For information claimed to be confidential, the Permittee may furnish such records directly to the EPA upon request along with a claim of confidentiality.

N. **Duty to Supplement** [15A NCAC 02Q .0507(f)]

The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information to the DAQ. The Permittee shall also provide additional information as necessary to address any requirement that becomes applicable to the facility after the date a complete permit application was submitted but prior to the release of the draft permit.

O. **Retention of Records** [15A NCAC 02Q .0508(f) and 02Q .0508(l)]

The Permittee shall retain records of all required monitoring data and supporting information for a period of at least five years from the date of the monitoring sample, measurement, report, or application. Supporting information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring information, and copies of all reports required by the permit. These records shall be maintained in a form suitable and readily available for expeditious inspection and review. Any records required by the conditions of this permit shall be kept on site and made available to DAQ personnel for inspection upon request.

P. **Compliance Certification** [15A NCAC 02Q .0508(n)]

The Permittee shall submit to the DAQ and the EPA (Air Enforcement Branch, EPA, Region 4, 61 Forsyth Street SW, Atlanta, GA 30303 or through the EPA CEDRI) postmarked on or before March 1 a compliance certification (for the preceding calendar year) by a responsible official with all terms and conditions in the permit (including emissions limitations, standards, or work practices), except for conditions identified as being State-enforceable Only. It shall be the responsibility of the current owner to submit a compliance certification for the entire year regardless of who owned the facility during the year. The compliance certification shall comply with additional requirements as may be specified under Sections 114(a)(3) or 504(b) of the Federal Clean Air Act. The compliance certification shall specify:

1. the identification of each term or condition of the permit that is the basis of the certification;
2. the compliance status (with the terms and conditions of the permit for the period covered by the certification);
3. whether compliance was continuous or intermittent;
4. the method(s) used for determining the compliance status of the source during the certification period;
5. each deviation and take it into account in the compliance certification; and
6. as possible exceptions to compliance, any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR Part 64 (CAM) occurred.

Q. **Certification by Responsible Official** [15A NCAC 02Q .0520]

A responsible official shall certify the truth, accuracy, and completeness of any application form, report, or compliance certification required by this permit. All certifications shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

R. **Permit Shield for Applicable Requirements** [15A NCAC 02Q .0512]

1. Compliance with the terms and conditions of this permit shall be deemed compliance with applicable requirements, where such applicable requirements are included and specifically identified in the permit as of the date of permit issuance.
2. A permit shield shall not alter or affect:
 - a. the power of the Commission, Secretary of the Department, or Governor under NCGS 143-215.3(a)(12), or EPA under Section 303 of the Federal Clean Air Act;
 - b. the liability of an owner or operator of a facility for any violation of applicable requirements prior to the effective date of the permit or at the time of permit issuance;
 - c. the applicable requirements under Title IV; or
 - d. the ability of the Director or the EPA under Section 114 of the Federal Clean Air Act to obtain information to determine compliance of the facility with its permit.

3. A permit shield does not apply to any change made at a facility that does not require a permit or permit revision made under 15A NCAC 02Q .0523.
4. A permit shield does not extend to minor permit modifications made under 15A NCAC 02Q .0515.

S. **Termination, Modification, and Revocation of the Permit** [15A NCAC 02Q .0519]

The Director may terminate, modify, or revoke and reissue this permit if:

1. the information contained in the application or presented in support thereof is determined to be incorrect;
2. the conditions under which the permit or permit renewal was granted have changed;
3. violations of conditions contained in the permit have occurred;
4. the EPA requests that the permit be revoked under 40 CFR 70.7(g) or 70.8(d); or
5. the Director finds that termination, modification, or revocation and reissuance of the permit is necessary to carry out the purpose of NCGS Chapter 143, Article 21B.

T. **Insignificant Activities** [15A NCAC 02Q .0503]

Because an emission source or activity is insignificant does not mean that the emission source or activity is exempted from any applicable requirement or that the owner or operator of the source is exempted from demonstrating compliance with any applicable requirement. The Permittee shall have available at the facility at all times and made available to an authorized representative upon request, documentation, including calculations, if necessary, to demonstrate that an emission source or activity is insignificant.

U. **Property Rights** [15A NCAC 02Q .0508(i)(8)]

This permit does not convey any property rights in either real or personal property or any exclusive privileges.

V. **Inspection and Entry** [15A NCAC 02Q .0508(l) and NCGS 143-215.3(a)(2)]

1. Upon presentation of credentials and other documents as may be required by law, the Permittee shall allow the DAQ, or an authorized representative, to perform the following:
 - a. enter the Permittee's premises where the permitted facility is located or emissions-related activity is conducted, or where records are kept under the conditions of the permit;
 - b. have access to and copy, at reasonable times, any records that are required to be kept under the conditions of the permit;
 - c. inspect at reasonable times and using reasonable safety practices any source, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - d. sample or monitor substances or parameters, using reasonable safety practices, for the purpose of assuring compliance with the permit or applicable requirements at reasonable times.Nothing in this condition shall limit the ability of the EPA to inspect or enter the premises of the Permittee under Section 114 or other provisions of the Federal Clean Air Act.
2. No person shall refuse entry or access to any authorized representative of the DAQ who requests entry for purposes of inspection, and who presents appropriate credentials, nor shall any person obstruct, hamper, or interfere with any such authorized representative while in the process of carrying out his official duties. Refusal of entry or access may constitute grounds for permit revocation and assessment of civil penalties.

W. **Annual Fee Payment** [15A NCAC 02Q .0508(i)(10)]

1. The Permittee shall pay all fees in accordance with 15A NCAC 02Q .0200.
2. Payment of fees may be by check or money order made payable to the N.C. Department of Environmental Quality. Annual permit fee payments shall refer to the permit number.
3. If, within 30 days after being billed, the Permittee fails to pay an annual fee, the Director may initiate action to terminate the permit under 15A NCAC 02Q .0519.

X. **Annual Emission Inventory Requirements** [15A NCAC 02Q .0207]

The Permittee shall report by **June 30 of each year** the actual emissions of each air pollutant listed in 15A NCAC 02Q .0207(a) from each emission source within the facility during the previous calendar year. The report shall be in or on such form as may be established by the Director. The accuracy of the report shall be certified by a responsible official of the facility.

Y. **Confidential Information** [15A NCAC 02Q .0107 and 02Q .0508(i)(9)]

Whenever the Permittee submits information under a claim of confidentiality pursuant to 15A NCAC 02Q .0107, the Permittee may also submit a copy of all such information and claim directly to the EPA upon request. All requests for confidentiality must be in accordance with 15A NCAC 02Q .0107.

- Z. **Construction and Operation Permits** [15A NCAC 02Q .0100 and .0300]
A construction and operating permit shall be obtained by the Permittee for any proposed new or modified facility or emission source which is not exempted from having a permit prior to the beginning of construction or modification, in accordance with all applicable provisions of 15A NCAC 02Q .0100 and .0300.
- AA. **Standard Application Form and Required Information** [15A NCAC 02Q .0505 and .0507]
The Permittee shall submit applications and required information in accordance with the provisions of 15A NCAC 02Q .0505 and .0507.
- BB. **Financial Responsibility and Compliance History** [15A NCAC 02Q .0507(d)(3)]
The DAQ may require an applicant to submit a statement of financial qualifications and/or a statement of substantial compliance history.
- CC. **Refrigerant Requirements (Stratospheric Ozone and Climate Protection)** [15A NCAC 02Q .0501(d)]
1. If the Permittee has appliances or refrigeration equipment, including air conditioning equipment, which use Class I or II ozone-depleting substances such as chlorofluorocarbons and hydrochlorofluorocarbons listed as refrigerants in 40 CFR Part 82 Subpart A Appendices A and B, the Permittee shall service, repair, and maintain such equipment according to the work practices, personnel certification requirements, and certified recycling and recovery equipment specified in 40 CFR Part 82 Subpart F.
2. The Permittee shall not knowingly vent or otherwise release any Class I or II substance into the environment during the repair, servicing, maintenance, or disposal of any such device except as provided in 40 CFR Part 82 Subpart F.
3. The Permittee shall comply with all reporting and recordkeeping requirements of 40 CFR 82.166. Reports shall be submitted to the EPA or its designee as required.
- DD. **Prevention of Accidental Releases - Section 112(r)** [15A NCAC 02Q .0508(h)]
If the Permittee is required to develop and register a Risk Management Plan with EPA pursuant to Section 112(r) of the Clean Air Act, then the Permittee is required to register this plan in accordance with 40 CFR Part 68.
- EE. **National Emission Standards Asbestos – 40 CFR Part 61, Subpart M** [15A NCAC 02D .1110]
The Permittee shall comply with all applicable standards for demolition and renovation activities pursuant to the requirements of 40 CFR Part 61, Subpart M. The permittee shall not be required to obtain a modification of this permit in order to perform the referenced activities.
- FF. **Title IV Allowances** [15A NCAC 02Q .0508(i)(1)]
This permit does not limit the number of Title IV allowances held by the Permittee, but the Permittee may not use allowances as a defense to noncompliance with any other applicable requirement. The Permittee's emissions may not exceed any allowances that the facility lawfully holds under Title IV of the Federal Clean Air Act.
- GG. **Air Pollution Emergency Episode** [15A NCAC 02D .0300]
Should the Director of the DAQ declare an Air Pollution Emergency Episode, the Permittee will be required to operate in accordance with the Permittee's previously approved Emission Reduction Plan or, in the absence of an approved plan, with the appropriate requirements specified in 15A NCAC 02D .0300.
- HH. **Registration of Air Pollution Sources** [15A NCAC 02D .0202]
The Director of the DAQ may require the Permittee to register a source of air pollution. If the Permittee is required to register a source of air pollution, this registration and required information will be in accordance with 15A NCAC 02D .0202(b).
- II. **Ambient Air Quality Standards** [15A NCAC 02D .0501(c)]
In addition to any control or manner of operation necessary to meet emission standards specified in this permit, any source of air pollution shall be operated with such control or in such manner that the source shall not cause the ambient air quality standards in 15A NCAC 02D .0400 to be exceeded at any point beyond the premises on which the source is located. When controls more stringent than named in the applicable emission standards in this permit are required to prevent violation of the ambient air quality standards or are required to create an offset, the permit shall contain a condition requiring these controls.
- JJ. **General Emissions Testing and Reporting Requirements** [15A NCAC 02Q .0508(i)(16)]

Emission compliance testing shall be by the procedures of Section .2600, except as may be otherwise required in Rules .0524, .1110, or .1111 of Subchapter 02D. If emissions testing is required by this permit or the DAQ or if the Permittee submits emissions testing to the DAQ to demonstrate compliance for emission sources subject to Rules .0524, .1110, or .1111, the Permittee shall provide and submit all notifications, conduct all testing, and submit all test reports in accordance with the requirements of 15A NCAC 02D .0524, .1110, or .1111, as applicable. Otherwise, if emissions testing is required by this permit or the DAQ or if the Permittee submits emissions testing to the DAQ to demonstrate compliance, the Permittee shall perform such testing in accordance with 15A NCAC 02D .2600 and follow the procedures outlined below:

1. The owner or operator of the source shall arrange for air emission testing protocols to be provided to the Director prior to air pollution testing. Testing protocols are not required to be pre-approved by the Director prior to air pollution testing. The Director shall review air emission testing protocols for pre-approval prior to testing if requested by the owner or operator at least **45 days** before conducting the test.
2. Any person proposing to conduct an emissions test to demonstrate compliance with an applicable standard shall notify the Director at least **15 days** before beginning the test so that the Director may at his option observe the test.
3. The owner or operator of the source shall arrange for controlling and measuring the production rates during the period of air testing. The owner or operator of the source shall ensure that the equipment or process being tested is operated at the production rate that best fulfills the purpose of the test. The individual conducting the emission test shall describe the procedures used to obtain accurate process data and include in the test report the average production rates determined during each testing period.
4. Two copies of the final air emission test report shall be submitted to the Director not later than **30 days** after sample collection unless otherwise specified in the specific conditions. The owner or operator may request an extension to submit the final test report. The Director shall approve an extension request if he finds that the extension request is a result of actions beyond the control of the owner or operator.
 - a. The Director shall make the final determination regarding any testing procedure deviation and the validity of the compliance test. The Director may:
 - i. Allow deviations from a method specified under a rule in this Section if the owner or operator of the source being tested demonstrates to the satisfaction of the Director that the specified method is inappropriate for the source being tested.
 - ii. Prescribe alternate test procedures on an individual basis when he finds that the alternative method is necessary to secure more reliable test data.
 - iii. Prescribe or approve methods on an individual basis for sources or pollutants for which no test method is specified in 15A NCAC 02D .2600 if the methods can be demonstrated to determine compliance of permitted emission sources or pollutants.
 - b. The Director may authorize the DAQ to conduct independent tests of any source subject to a rule in 15A NCAC 02D to determine the compliance status of that source or to verify any test data submitted relating to that source. Any test conducted by the Division of Air Quality using the appropriate testing procedures described in 15A NCAC 02D .2600 has precedence over all other tests.

KK. Reopening for Cause [15A NCAC 02Q .0517]

1. A permit shall be reopened and revised under the following circumstances:
 - a. additional applicable requirements become applicable to a facility with remaining permit term of three or more years;
 - b. additional requirements (including excess emission requirements) become applicable to a source covered by Title IV;
 - c. the Director or EPA finds that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit; or
 - d. the Director or EPA determines that the permit must be revised or revoked to assure compliance with the applicable requirements.
2. Any permit reopening shall be completed or a revised permit issued within 18 months after the applicable requirement is promulgated. No reopening is required if the effective date of the requirement is after the expiration of the permit term unless the term of the permit was extended pursuant to 15A NCAC 02Q .0513(c).
3. Except for the state-enforceable only portion of the permit, the procedures set out in 15A NCAC 02Q .0507, .0521, or .0522 shall be followed to reissue the permit. If the State-enforceable only portion of the permit is reopened, the procedures in 15A NCAC 02Q .0300 shall be followed. The proceedings shall affect only those parts of the permit for which cause to reopen exists.
4. The Director shall notify the Permittee at least 60 days in advance of the date that the permit is to be reopened, except in cases of imminent threat to public health or safety the notification period may be less than 60 days.

5. Within 90 days, or 180 days if the EPA extends the response period, after receiving notification from the EPA that a permit needs to be terminated, modified, or revoked and reissued, the Director shall send to the EPA a proposed determination of termination, modification, or revocation and reissuance, as appropriate.

LL. Reporting Requirements for NonOperating Equipment [15A NCAC 02Q .0508(i)(16)]

The Permittee shall maintain a record of operation for permitted equipment noting whenever the equipment is taken from and placed into operation. When permitted equipment is not in operation, the requirements for testing, monitoring, and recordkeeping are suspended until operation resumes.

MM. Fugitive Dust Control Requirement [15A NCAC 02D .0540]

As required by 15A NCAC 02D .0540 "Particulates from Fugitive Dust Emission Sources," the Permittee shall not cause or allow fugitive dust emissions to cause or contribute to substantive complaints or excess visible emissions beyond the property boundary. If substantive complaints or excessive fugitive dust emissions from the facility are observed beyond the property boundaries for six minutes in any one hour (using Reference Method 22 in 40 CFR, Appendix A), the owner or operator may be required to submit a fugitive dust plan as described in 02D .0540(f).

"Fugitive dust emissions" means particulate matter from process operations that does not pass through a process stack or vent and that is generated within plant property boundaries from activities such as: unloading and loading areas, process areas, stockpiles, stock pile working, plant parking lots, and plant roads (including access roads and haul roads).

NN. Specific Permit Modifications [15A NCAC 02Q .0501 and .0523]

1. For modifications made pursuant to 15A NCAC 02Q .0501(b)(2), the Permittee shall file a Title V Air Quality Permit Application for the air emission source(s) and associated air pollution control device(s) on or before 12 months after commencing operation.
2. For modifications made pursuant to 15A NCAC 02Q .0501(c)(2), the Permittee shall not begin operation of the air emission source(s) and associated air pollution control device(s) until a Title V Air Quality Permit Application is filed and a construction and operation permit following the procedures of Section .0500 (except for Rule .0504 of this Section) is obtained.
3. For modifications made pursuant to 502(b)(10), in accordance with 15A NCAC 02Q .0523(a)(1)(C), the Permittee shall notify the Director and EPA (Air Permitting Branch, EPA, Region 4, 61 Forsyth Street SW, Atlanta, GA 30303 or through the EPA CEDRI) in writing at least seven days before the change is made.
 - a. The written notification shall include:
 - i. a description of the change at the facility;
 - ii. the date on which the change will occur;
 - iii. any change in emissions; and
 - iv. any permit term or condition that is no longer applicable as a result of the change.
 - b. In addition to this notification requirement, with the next significant modification or Air Quality Permit renewal, the Permittee shall submit a page "E5" of the application forms signed by the responsible official verifying that the application for the 502(b)(10) change/modification, is true, accurate, and complete. Further note that modifications made pursuant to 502(b)(10) do not relieve the Permittee from satisfying preconstruction requirements.

OO. Third Party Participation and EPA Review [15A NCAC 02Q .0521, .0522 and .0525(7)]

For permits modifications subject to 45-day review by the federal EPA, EPA's decision to not object to the proposed permit is considered final and binding on the EPA and absent a third party petition, the failure to object is the end of EPA's decision-making process with respect to the revisions to the permit. The time period available to submit a public petition pursuant to 15A NCAC 02Q .0518 begins at the end of the 45-day EPA review period.